

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>		<b>1. CONTRACT ID CODE</b>		<b>PAGE OF PAGES</b> 1   2	
<b>2. AMENDMENT/MODIFICATION NO.</b> A002		<b>3. EFFECTIVE DATE</b> May 7, 2014		<b>4. REQUISITION/PURCHASE REQ. NO.</b>	
<b>5. PROJECT NO. (If applicable)</b>		<b>6. ISSUED BY</b>		<b>7. ADMINISTERED BY (If other than Item 6)</b>	
Contracting Officer American Embassy Dhaka, Bangladesh		Contracting Officer American Embassy Dhaka, Bangladesh			
<b>8. NAME AND ADDRESS OF CONTRACTOR (NO., street,city,county,State,and ZIP Code)</b>		<b>9a. AMENDMENT OF SOLICITATION NO.</b> X SBG30014Q0644		<b>9b. DATED (SEE ITEM 11)</b> X April 27, 2014	
		<b>10a. MODIFICATION OF CONTRACT/ORDER NO.</b>		<b>10b. DATED (SEE ITEM 13)</b>	
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>					
<p><input type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input type="checkbox"/> is not extended</p> <p>Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment;(b) By acknowledging receipt of this amendment on each copy of the offer submitted; or(c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers.</p> <p><b>FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.</b> If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.</p>					
<b>12. ACCOUNTING AND APPROPRIATION DATA (If required)</b>					
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b)					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
<b>E. IMPORTANT:</b> Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return ____ copies to the issuing office.					
<b>14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)</b>					
The solicitation # SBG30014Q0644 is hereby ammended due to changes requirements in the scope of work.					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
<b>15A. NAME AND TITLE OF SIGNER (Type or print)</b>			<b>16A. NAME OF CONTRACTING OFFICER</b>		
			Robert Blanchard - Contracting Officer		
<b>15B. NAME OF CONTRACTOR/OFFEROR</b>		<b>15C. DATE SIGNED</b>		<b>16B. UNITED STATES OF AMERICA</b>	
BY _____ (Signature of person authorized to sign)				BY _____ (Signature of Contracting Officer)	
				<b>16C. DATE SIGNED</b>	

SF30

Amendment # A002 of Solicitation # SBG30014Q0644

#	Existing SOW	Revised SOW
1.b	Existing wooden door is to be fitted. Matching well matured, seasoned solid wood (Chittagong teak or best quality available) is to be used for extra pieces at side and trim/joint as necessary. Design will be as existing one.	Existing wooden door is to be fitted. Matching well matured, seasoned solid wood (Chittagong teak or best quality available) is to be used for extra pieces at side and trim/joint as necessary. Design will be as existing one. <b>The gap on the door will to be filled with solid wooden block, anchored at both side and should be of same design and quality as existing door.</b>
3.b	Door, window: Well matured, seasoned solid wood (Chittagong teak or best quality available) is to be used. Size and design should match with the existing doors and windows.	Door, window: Well matured, seasoned solid wood (Chittagong teak or best quality available) is to be used. Size and design should match with the existing doors and windows. <b>Provision of emergency egress at window should be kept.</b>
5.b		<b>A peep hole is to be added at door to out.</b>
7.b	Construct wall and fit new wooden door. Well matured, seasoned solid wood (Chittagong teak or best quality available) is to be used. Size and design should match with the existing doors.	Construct <b>wooden partition</b> and fit new wooden door. Well matured, seasoned solid wood (Chittagong teak or best quality available) is to be used. Size and design should match with the existing doors. <b>The glazing on the door will remain as it is.</b>
10.a	Existing sliding glass door and sliding grill are to be moved to balcony line. Proper finishing work is to be done with similar type of material as surrounding.	Existing sliding glass door and sliding grill are to be moved to balcony line. Proper finishing work is to be done with similar type of material as surrounding. <b>Sliding grill will be fitted inside and sliding window shutter with mosquito net will be fitted outside. MS angle can be used at top and bottom to support window frame.</b>
12.b	Construct wall and window grill (MS) and sliding window with aluminum section and glass. Aluminum section as per U.S. Architectural Aluminum Manufacturer's Association (AAMA) standard specification is to be used. Fiber mesh should be used as mosquito mesh. Color and design should match with existing aluminum work.	Construct wall and window grill (MS) and sliding window with aluminum section and glass. Aluminum section as per U.S. Architectural Aluminum Manufacturer's Association (AAMA) standard specification is to be used. Fiber mesh should be used as mosquito mesh. Color and design should match with existing aluminum work. <b>Swing window grill will be fitted inside and sliding window shutter will be fitted outside to facilitate maintenance work.</b>
16.b	Sliding windows with aluminum section and glass should be fitted. Aluminum section as per U.S. Architectural Aluminum Manufacturer's Association (AAMA) standard specification is to be used. Fiber mesh should be used as mosquito mesh. Color and design should match with existing aluminum work.	Sliding windows with aluminum section and glass should be fitted. Aluminum section as per U.S. Architectural Aluminum Manufacturer's Association (AAMA) standard specification is to be used. Fiber mesh should be used as mosquito mesh. Color and design should match with existing aluminum work. <b>Provision of emergency egress at window should be kept at West.</b>
19.e		<b>Footer of the column should be adjusted with the existing brick foundation. Brick foundation cannot be dismantled or damaged.</b>