

United States Embassy Bogota

*SOLICITATION # SCO20016Q0016 Maintenance and Repair of Tennis & Basketball courts
Surface in Chancery compound*

Question # 1. Is it required to remove all painting or just the damaged areas?

Yes, all the painting must be removed in order to assure that the existing concrete slab will be in acceptable condition for the new coats of paint.