

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES	
			J	1	3
2. AMENDMENT/MODIFICATION NO. 0002	3. EFFECTIVE DATE 25-Aug-2014	4. REQUISITION/PURCHASE REQ. NO. SEE SCHEDULE		5. PROJECT NO.(If applicable)	
6. ISSUED BY REGIONAL CONTRACTING OFFICE (RCO) BOGOTA CARRERA 45 NO. 24B-27 USMILGP CONTRACTING BOGOTA	CODE W913FT	7. ADMINISTERED BY (If other than item 6)		CODE	
		See Item 6			
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)			X	9A. AMENDMENT OF SOLICITATION NO. W913FT-14-T-0033	
			X	9B. DATED (SEE ITEM 11) 13-Aug-2014	
				10A. MOD. OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE			FACILITY CODE		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)					
a. This amendment is issued to respond to a question from a prospective offeror.					
b. All other terms and conditions remain unchanged.					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
			TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)		26-Aug-2014	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 1449 - CONTINUATION SHEET

The following have been added by full text:

PREGUNTAS Y RESPUESTAS

Preguntas y Respuestas
Building Materials

- 1) Pregunta: Las bolsas de mortero adhesivo, es para usar en paredes o pisos?
Respuesta: El Mortero es para usar en paredes.
- 2) Pregunta: Cual es el uso de las láminas de revestimiento compuesto?
Respuesta: Estas láminas serán usadas para cubrir las paredes exteriores con laminas de 28.5 cm de ancho x 365.76 de largo.
- 3) Pregunta: Por favor dar más especificaciones de las hojas corrugadas para techos.
Respuesta: Las hojas corrugadas para techos son de 2.43 metros de largo x 91.44 cm ancho x 1.94 cm de grosor.
- 4) Pregunta: Están solicitando una puerta de seguridad o es una puerta de acero para una casa.
Respuesta: Es una puerta de acero regular, 81.28 cm de ancho x 203.2 cm de largo x 4.45cm de grosor.
- 5) Pregunta: Dar medidas en metros cuadrados de las tabletas de piso laminado.
Respuesta: La medidas son 108 Metros cuadrados de 7mm de grosor x 29.72cm/40.64cm Ancho x 127-12.7cm / 20.32cm.
- 6) Pregunta: El estuco es un tipo especial o es el blanco regular.
Respuesta: Es mezcla de estuco regular blanco.

QUESTIONS AND ANSWERS

Questions and Answers
Building Materials

- 7) Question: The Bags of mortar, is this for walls or floors?
Response: The bags of mortar are for walls.
- 8) Question: What is the use for the Siding?
Response: The Siding is for cover exterior walls, is 11.22 in. long x 144 in width and 0.40 thickness.
- 9) Question: Please provide more specifications or a brand reference of the roofing panels.
Response: The roofing panels are panels that are 8ft long, 0.75 in. long, 36 in. width individually. That gets laid out in sections.
- 10) Question: Do you need a security door or a normal steel door for a room, please provide the measurements.
Response: Is a normal steel door, 32in W x 80 in. H door Thickness 1.75 in.
- 11) Question: Please provide the measurements in meters square of the Laminate Flooring.
Response: Measurements in square meters 7mm Thick x 7-11/16 in. Wide x 50-5/8 in. Length Laminate Flooring (24.33 sq.ft./Case)
- 12) Question: Is the stucco a special type or is regular Stucco Mix?
Response: Is regular mix stucco.

(End of Summary of Changes)