

**STATEMENT OF WORK  
(SOW)  
US Embassy Façade Lighting Set Up & Assembly**

**1. INTRODUCTION**

- 1.1 The United States Embassy in Santo Domingo has been directed to procure services to provide all material and labor to create a weather-proof continuous lighting display on the south façade of the NOB Building. Contractor is to use a light that can illuminate the entire 50' tau face above the consular section roof.
- 1.2 The work consists of, but is not limited to: Install conduit and wiring for electrical feeding of LED Lights. Excavation for installing these conduits in the garden area. The contractor shall follow the layout and specifications provided.
- 1.3 The Contractor shall complete all work, including landscaping and shall provide all labor and materials required under this contract for the lighting system set up. The price offered shall include all labor, materials, overhead (including cost of Workers' Compensation and Liability Insurance, which shall not be a direct reimbursement), and profit.

**1.4 EXECUTION**

- 1.4.1 Installation: Contractor is to provide temporary power, scaffolding, permanent circuitry and lighting controls in order to install the required lights.
- 1.4.2 Set up must be completed before 01 October 2015.
- 1.4.3 Lights are to be fed from CCAC electrical room; Wires are to be 2 No. 6 THHN wires (Phase and Neutral), 1 No. 10 THHN wire (Ground cable), 1 No. 6 THHN wire for control cabling, PVC conduit (underground cabling in the garden area), IMC conduit for outdoor application and EMT conduit for indoor (CCAC). Contractor is to install junction boxes as required by NFPA 70.
- 1.4.4 Contractor is to include excavation and reestablishment of the garden area.
- 1.4.5 Contractor has to fulfill the requirements of NFPA 70 for the complete execution of this project.
- 1.4.6 Contractor is to provide 2 years of warranty.
- 1.4.7 Contractor is to provide instruction to Embassy Staff on How to operate Lighting System (One day training).
- 1.4.8 Materials are to be previously inspected before arrival.
- 1.4.9 Contractor is to provide transport, tools and submission of workers ID'S and installation experience of each worker.
- 1.4.2 Contractor shall clean and prepare surfaces for follow on work according to the drawings. The Contractor shall ensure that during construction there are measures for control of unnecessary noise, dust and other contaminants. Also, the contractor shall ensure that personnel will observe safety measures in accordance with local regulations and norms. The Contractor shall be responsible for debris removal and shall leave the work area clean after the end of each work day.
- 1.4.3 Contractor personnel shall not wander outside of the work area at any time. The contractor will be responsible to remove prior approval of the Contracting Officer Representative (COR) all items that may be disrupting their work and put it back in place later on. They are responsible to cover and protect the surrounding to avoid any potential damages.

**END OF STATEMENT OF WORK**

## **Annex 1**

- a) Name of the project
- b) Date of beginning
- c) Date of completion
- d) Pricing of the project
- e) Problems contractor had to overcome
- f) Solutions provided to overcome this problem
- g) Contractor sign
- h) Submit a personnel diagram of each project completed
- i) Submit the specifications required for the installation of this LED lighting system