



RFQ number PR5145885 supply only Split Pack Wall Mounted Air conditioning devices

The Embassy of the United States of America invites you to submit an offer for following products or equal. All offers should be according to the below specifications.

QTY	ITEM DESCRIPTION
150	<p>Split Pack Wall Mounted A/Cs</p> <p>1. GENERAL REQUIREMENTS This is a list of specifications for the air conditioning units needed</p> <p>2.SPECIFICATIONS</p> <p>2.1.Style: High wall split unit air conditioning 2.2.Type: Heat pump 2.3.Slendered: CE, UL or IEC listed 2.4.Power: 220Volt ±10% / 50 Hz / 1Ph 2.5.Cooling capacity: 24000 BTU/HR. at outdoor temp 35°C DBT and Indoor 23°C & EER 9.5 ±5% 2.6.Heating capacity: 24000 BTU/HR. at outdoor temp 7/6°C D/WBT and Indoor 20°C & COP 11 ±5% 2.7.Ambient conditions: Summer 52/21°C DBT / Winter 24/2°C DBT 2.8.Compressor: Rotary or scroll compressor 2.9.Accessories: Indoor Unit air filters Manual control button Wireless remote control with batteries Automatic air flow direction (horizontal and vertical) Self-diagnostic function Indoor wall hang bracket Outdoor wall support</p> <p>2.10.Tubing: Factory manufactured ready to install Provided from the same A/C unit manufacturer Pre-insulated, with factory flared and attachment fittings 9 meters of refrigerant tubing Tube shall be K type soft cooper coiled Flare type with nuts (factory flared) Size shall be according to manufacturer recommendation Tube shall be ASTM B 88 standards</p> <p>2.11.Documents: Operation and installation manuals Any accessories required for complete and safe operation</p>

Goods to be delivered @ our below Despatch Agency address (Please specify inland freight costs / If any) and payment will be according to Dept of State regulations via Government Purchase Order (Net 30 Terms).

EGYPT Delivery Address
American Embassy Warehouse
Zahraa El Maadi
Maadi, Cairo - Egypt
Tel: +20 (2) 2797-3922

If you would like to submit a quotation, you should thoroughly examine the above required specifications and submit your offer to CairoContracts@state.gov.