

Addendum No 1
FOR
CMR Electrical Replacement Services
At
US Embassy Helsinki

4/10/2013

Project 2013-004

1.0 INTRODUCTION

1.1 Overview:

This Addendum becomes a part of the Statement of Work dated 4-8-2013.

2.0 SCOPE OF WORK MODIFICATIONS

2.1 The Contractor shall conceal all exposed telephone wiring on the first, second and third floors.

2.2 All wall, floor and ceiling repairs in the five bathrooms to be renovated shall be the responsibility of the plumbing contractor and are not part of this work.

3.0 ALTERNATES

3.1 The following alternates shall be provided in addition to the base bid for work.

1. Alternate 1 (deduct from base bid) – Combining third and fourth floor circuiting into one panel on the second floor.
2. Alternate 2 (addition to base bid) - Contractor shall install CAT6 and fiber lines from basement to each sub-panel for future use.
3. Alternate 3 (addition to base bid) – Contractor to supply and install circuit breaker type sub-panel for sauna.

END OF ADDENDUM NO 1