

July 29, 2015

**Emergency Sanctuary Project
U.S. EMBASSY ATHENS, GREECE**

QUESTIONS AND ANSWERS

(Site Visit held on 07/23/2015)

Q1. Are the paints of penetration for HVAC and Electrical wiring to the Hard line Walls will have FIRE STOPS retardant sealants, and if yes what kind (e.g HILTI TYPE).

A1. Please see drawing CMPD A0.02, note 2 and attached specification 07840.

Q2. Please identify the type of Special Acrylic Color as a final COLOR COATING layer to the Epoxy Primer , since not all Acrylic paints are suitable, and what kind?

A2. Please see drawing CMPD A0.02 note 5 and specification section 09912.

Q3. Shall we seal the paints of the Hardlline walls attached to floors and Ceilings during the works.

A3. Yes, compartment has to be completely sealed according to attached specification 07840.