

September 19, 2011
Solar panels and triple energy boilers for GO Residences
U.S. EMBASSY ATHENS, GREECE

Site Visit Attendees

Name/Company

Christos Papahristou/ Papahristou Company
George Kapantais/D & H Arvanitis
Alexandros Lantis / Globe Williams
Christos Argirakis / Globe Williams
George Papadopoulos / In Maint SA
Andreas Vryonis / Vryonis Constructions
Stamatis Valindras / Vryonis Constructions
Stavroula Kokkota / Tsimberdonis Constructions
Alexandros Chronis/ Hardex
Maria Kourampa/ Hardex

Embassy Staff:

Sergey Olhovsky
Nikos Papazoglou
Petros Panayiotou
Aleka Kouyentaki
George Dimitrokalis

QUESTIONS AND ANSWERS

(Site Visits held on 09/14/2011 and 09/15/2011)

Q1. Please provide detailed specifications of circulators (WILO) per residence.

A1. Please refer to the revised SOW.

Q2. Please provide pipe section per residence.

A2. Please refer to the revised SOW.

Q3. Is there a possibility of the crew working on weekends?

A3. Please refer to section E – Deliveries or Performance, paragraph *Working Hours*.

Q4. Which residence has a recirculation system?

A4. Please refer to the revised SOW.

Q5. The technical specifications of boiler 200lt (SONNE) demands collector area 3.36m². Your suggestion is 2.4m². Please specify what is the preferred collector area?

A.5. Each residence will have at least $2.4 \times 2 = 4.8 \text{ m}^2$ of solar panels. Please proceed as described within the SOW.

Q6. What is the preferred brand for the expansion tank?

A6. Please refer to the revised SOW.