

1. - Historic log of maintenance for C27 and 3406 and for the panel. - Include dates and work done.

CATERPILLAR GENERATOR C27:

On February/04/2015 the following jobs were done:

- Air filter was changed
- Oil was changed
- Fuel filter was changed

CATERPILLAR GENERATOR 3406:

On January/28/2015 the following jobs were done:

- Air filter was changed
- Oil was changed
- Fuel filter was changed

On March/16/2015 the following jobs were done:

- Refrigerant was changed
- Radiator maintenance and repair of leak.

2.-Is the contractor allowed to bring a 3-Ton VAN with tools inside the compound, to check Utility Generator (C27) and North Compound Generator?

Paragraph 6.0 subsection 6.2 describes access for personnel and 6.2.1 describes the requirements for vehicles. In addition to these sections, in accordance with subsection 11.1 describing property damage, the contractor should make every attempt to minimize damage to the compound grounds. If excessive damage is found due to contractor negligence, the COR will request to the Contracting Officer that contractors are held liable for financial obligations for repairs.

6.2 Personnel Security. The Government reserves the right to deny access to U.S.-owned and U.S.-operated facilities to any individual. The Contractor shall provide the names, biographic data and police clearance on all Contractor personnel who shall be used on this Contract prior to their utilization. Submission of information shall be made within 5 days of award of contract. No technician will be allowed on site without prior authorization. Note: this may include cleared personnel if advance notice of visit is not given at least one week before the scheduled visit.

6.2.1 Vehicles. Contractor vehicles will not be permitted inside the Consulate compound without prior approval. If you need to have vehicle access please submit your vehicle information (Make, Model, License Plate #) along with a written justification as to why access is necessary. This should be submitted to the Facility Manager at least one (1) week prior to the visit.

11.1 Personal Injury, Property Loss or Damage (Liability). The Contractor assumes absolute responsibility and liability for any and all personal injuries or death and property damage or losses suffered due to negligence of the Contractor's personnel in the performance of this Contract. The Contractor's assumption of absolute liability is independent of any insurance policies.

3. - Is the contractor allowed to bring inside de the compound a 4.5 -Tons Truck carrying the Load Bank Resistor, to test the C27 Generator located in the Utility Room and also North Compound Generator ?

Paragraph 6.0 subsection 6.2 describes access for personnel and 6.2.1 describes the requirements for vehicles. In addition to these sections, in accordance with subsection 11.1 describing property damage, the contractor should make every attempt to minimize damage to the compound grounds. If excessive damage is found due to contractor negligence, the COR will request to the Contracting Officer that contractors are held liable for financial obligations for repairs. Reference sections within the solicitation.

4.-Are the technicians allowed to bring inside the compound (only in the Utility room- not to the NAB building) a Tablet to follow the check list and perform the maintenance activities ?

The use of tablet devices to perform necessary tasks associated with the terms of the contract will be at the discretion of the U.S. Consulate's Security office. If permitted, the wireless and Bluetooth capabilities must be deactivated prior to entering the Consulate facility. Contractors are required to submit all tools, equipment, and electronic devices' information (Make, Model, and Serial Numbers) along with a written justification as to why access is necessary for this equipment. Additionally, pursuant to U.S. Consulate's security policy, all photographs of the Consulate grounds and compound buildings, including all exterior and interior areas are prohibited. On occasion, however, photographs may be permitted on a case-by-case basis following the COR and security office review and authorization. Therefore, clearance for all photography-related activities within Consulate facilities should be pre-coordinated and cleared with the COR and security office.