

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE OF PAGES
2. AMENDMENT/MODIFICATION NO.		3. EFFECTIVE DATE	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)
		06-02-2014	PR3297038-A001	
6. ISSUED BY CODE		H800	7. ADMINISTERED BY (If other than Item 6) CODE	
AMERICAN EMBASSY TEGUCIGALPA GSO, ACQUISITIONS UNIT, ATTN :GSO TEGUCIGALPA, HONDURAS			AMERICAN EMBASSY TEGUCIGALPA GSO, ACQUISITIONS UNIT, ATTN :GSO TEGUCIGALPA, HONDURAS	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO.
				SHO80014Q0021
				9B. DATED (SEE ITEM 11)
				10A. MODIFICATION OF CONTRACT/ORDER NO
				10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
(a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)


**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return 1 copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)
The purpose of this modification is to Amend the RFQ by extending the period to submit the offers. Submit offers in a sealed envelope on or before 10:00am June 4, 2014. Submit offers via e-mail with all the requested information attached to proctgu@state.gov before 4:00pm on June 3, 2014.
Additionally, Line Items 1-3 include their site reference and Line Item No 4 has been edited to eliminate the installation services and change the delivery site to BASE HAM.
Attached are the Q&A which are made part of this solicitation.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED
(Signature of person authorized to sign)		 (Signature of Contracting Officer)	5/30/2014

11. SCHEDULE

(Include applicable Federal, State and local taxes)

ITEM NO. (a)	SUPPLIES/SERVICES (b)	QUANTITY (c)	UNIT (d)	UNIT PRICE (e)	AMOUNT (f)
1	<p>Supply, delivery and installation of Generator and ATS at Site (1) Lomas del Guijarro (Reference Calle Niza) Generator Diesel Fueled Generator fully integrated power generation system, Capacity 12kw Emergency, 11KW Prime 240/120 VAC 1 phase, Dual Voltage 1800 rpm, 60 Hz Sound-attenuated and weather protective enclosures At least 24 hours of continuous operational time . ATS Same brand name as the generator Transfer switches up to 240 VAC, 50 Hz or 60 Hz, rated for 100 and 200 continuous amperes, Selectable exercise at repeatable intervals.</p> <p>Funding Information: Total: \$0.00 2100-2014--21__420201D14----- \$0.00 OMA</p>	1.00	EA	\$0.00	\$0.00
2	<p>Supply, delivery and installation of Generator and ATS at Site (2) Lomas del Guijarro (Reference Calle Praga) Generator Diesel Fueled Generator fully integrated power generation system, Capacity 12kw Emergency, 11KW Prime 240/120 VAC 1 phase, Dual Voltage 1800 rpm, 60 Hz Sound-attenuated and weather protective enclosures At least 24 hours of continuous operational time . ATS Same brand name as the generator Transfer switches up to 240 VAC, 50 Hz or 60 Hz, rated for 100 and 200 continuous amperes, Selectable exercise at repeatable intervals.</p> <p>Funding Information: Total: \$0.00 2100-2014--21__420201D14----- \$0.00 OMA</p>	1.00	EA	\$0.00	\$0.00
3	<p>Supply, delivery and installation of Generator and ATS at Site (3) Lomas del Guijarro (Reference Apartamento FAMA) Generator Diesel Fueled Generator fully integrated power generation system, Capacity 12kw Emergency, 11KW Prime 240/120 VAC 1 phase, Dual Voltage 1800 rpm, 60 Hz Sound-attenuated and weather protective enclosures At least 24 hours of continuous operational time . ATS Same brand name as the generator Transfer switches up to 240 VAC, 50 Hz or 60 Hz, rated for 100 and 200 continuous amperes, Selectable exercise at repeatable intervals.</p> <p>Funding Information: Total: \$0.00 2100-2014--21__420201D14----- \$0.00 OMA</p>	1.00	EA	\$0.00	\$0.00

4	<p>Supply and delivery of Generator and ATS at BASE HAM Generator Diesel Fueled Generator fully integrated power generation system, Capacity 12kw Emergency, 11KW Prime 240/120 VAC 1 phase, Dual Voltage 1800 rpm, 60 Hz Sound-attenuated and weather protective enclosures At least 24 hours of continuous operational time . ATS Same brand name as the generator Transfer switches up to 240 VAC, 50 Hz or 60 Hz, rated for 100 and 200 continuous amperes, Selectable exercise at repeatable intervals. Funding Information: Total: \$0.00 2100-2014-21__420201D14----- OMA</p>	1.00	EA	\$0.00	\$0.00
	<p style="text-align: right;">\$0.00</p>				

Questions and Answers

RFQ SHO80014Q0021: Supply, Delivery and Installation of Four (4) 12KW Generators and ATS

Q1. The offer must include maintenance for 2 years. Do you need to describe the maintenance or quote the maintenance for 24 months? If we need to quote maintenance we need an estimate of the number of hours the generators will be working on a daily basis.

A1. Maintenance plan should be quoted according to the standards dictated by the manufacturer.

Q2. The ATS must be NEMA1 or NEMA3. In case of being NEMA3, could you accept ATS NEMA 1 with a cabinet to protect it?

A2. Quote NEMA3.

Q3. Will you allow ATS to be a different brand than the generator, if they are compatible?

A3. Yes, as long as they are compatible.

Q4. Since each generator has to have a back up capacity of 24 hrs; do we need to quote an additional tank? If so what capacity?

A4. It will depend on the rate the generator consumes the fuel, however out of experience we normally have used at least 20 gallon tanks.

Q5. In the three (3) installation sites there needs to be a concrete slab built, considering that in site 3 (Apartamentos Fama) that will damage the floor, is it possible to place the generator over wood slabs.

A5. Yes, you can place the generator on properly treated wood base (posts or pillars).

Q6. Do we need to include accessories as block warmer and battery charger?

A6. Yes, although they normally come with the generator.

Q7. Warranty of 24 months must be without any hour limit?

A7. 24 months or 800 hours.

Q8. What are the specs for the installation of the equipment, kind of tubing, electric wiring etc?

A8. Two cables No 2 for live lines, one cable No 1 for the neutral line and one cable No 8 for the signals. PVC 1 1/2" for tubing.

Q9. Can we quote a generator that comes close to what you are requesting in case we don't have any model close to the capacity you need.

A9.Only quote 12KW.

Q10. The additional gas tank needs to be an original or can it be built locally.

A10.It can be either as long as it has good quality and is covered by the same warranty as the generator. If built locally it must be double walled.

Q11. What are the payment terms?

A.11 Payment will be made upon delivery. Wire transfer takes around 15 to 20 days after process is started.