

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT		1. CONTRACT ID CODE	Page 1 of 3
2. AMENDMENT/MODIFICATION NO. A001	3. EFFECTIVE DATE 04/30/2015	4.	5. PROJECT NO. (If applicable)
6. ISSUED BY AMERICAN EMBASSY NEW DELHI 9000 NEW DELHI PL, ATTN: S/GSO WASHINGTON, DC 20521-9000 UNITED STATES	CODE IN650	7. ADMINISTERED BY (If other than Item 6) CODE AMERICAN EMBASSY NEW DELHI 9000 NEW DELHI PL, ATTN: S/GSO WASHINGTON, DC 20521-9000 UNITED STATES	
8. NAME AND ADDRESS OF CONTRACTOR (NO., street, city, county, State, and ZIP Code) NOVENDOR		<input checked="" type="checkbox"/> 9a. AMENDMENT OF SOLICITATION NO. SIN65015Q00587	
		9b. DATED (SEE ITEM 11) 04/20/2015	
		10a. MODIFICATION OF CONTRACT/ORDER NO.	
		10b. DATED (SEE ITEM 13)	
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS			
<p>X The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers _____ is extended, <input checked="" type="checkbox"/> is not extended</p> <p>Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers.</p> <p>FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.</p>			
12. ACCOUNTING AND APPROPRIATION DATA (If required)			
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.			
—	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.		
—	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b)		
—	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:		
—	D. OTHER (Specify type of modification and authority)		
E. IMPORTANT: Contractor _____ is not, _____ is required to sign this document and return _____ copies to the issuing office.			
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)			
The purpose of this amendment is for the following:			
1.) Response to Question; (See page 2)			
NOTE: Proposal Due Date Remains unchanged.			
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.			
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME OF CONTRACTING OFFICER Kris Arvind	
15B. NAME OF CONTRACTOR/OFFEROR BY _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA, BY (Signature of Contracting Officer)	16C. DATE SIGNED 04/30/2015

SECTION 1.) Response to Submitted Questions

1. In given control parameters for Cooling Tower Open loop System (Page No. 8), you have mentioned the Hardness- 1200 PPM, which is very high. Also, the TDS is not mentioned in given parameters. So, pls confirm the TDS & Hardness?

Hardness shall be less than 80 ppm and the TDS shall be less than 1200 ppm.

2. Please confirm the Operation time of each plant (Chancery, American Center & HVAC) in a year?

Chancery chiller operates 365 days in a year. American center chiller works for 9 - 10 months in a year.