

QUESTIONS AND ANSWERS

**Solicitation No. SIZ100-12-R-0027
East End Concrete Patios and BBQ Grills
U.S. EMBASSY – BAGHDAD, IRAQ**

Q1. Please clarify the exact quantity of the Government-Furnished BBQ Grills that must be installed by the contractor - are they 22ea (Bid Form) or 14ea (SOW).

A1. There are 22 grilles, one at each patio. 14 is incorrect. The grilles are mounted on a 75 mm pipe column. See detail 4/A2 for mounting plate and connection. Please refer to Amendment #1.



Q2. What are the dimensions of the proposed concrete patios types A & B?

A2. Please refer to drawing C103 which shows the dimensions. Drawings were provided during the site visit.

Q3. Please clarify the types of proposed patios, i.e., bistro, outdoor D/R, outdoor L/R.

A3. There are two types of patios, A and B, dimensions shown on C103. Please ignore reference to “bistro”, “outdoor D/R”, or “outdoor L/R”. They are not relevant designations.

Q4. Scope of Work, Section 4.2 - East End Concrete Patios & Oasis, Paragraph B.1. – Please clarify if the stamp must only be provided by a U.S. PE structural engineer or a local structural engineer would be accepted.

A4. Certified Iraqi or other nationally recognized structural engineers are acceptable. Submittals will be reviewed against the US standards noted.