

# US Embassy Baghdad

## Solicitation S-IZ100-12-R-0033

### Civil Work

for the installation of Government furnished valves  
on the US Embassy Compound Water Mains

## Bidding Questions & Answers

May 20, 2012

1. **Question:** Are the valve and joint restraint supplied from the US Government or from the contractor?

**Answer:**

The Insta-Valves and Joint restraints are GFE (Government Furnished Equipment). The valves are installed by USG as well. Contractor provides excavation, backfill and coordination only.

\*\*\*\*\*

2. **Question:** The leakage water resulting from the work of the valve project should be drained outside the location. Is there a specific point for the drainage water?

**Answer:**

The valves are design for tapping under pressure. There is not much water leakage resulting from valve insertion; however any incidental water should drained to the street.

\*\*\*\*\*