


AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE		PAGE 1 OF 3
2. AMENDMENT/MODIFICATION NO. A001		3. EFFECTIVE DATE 03/25/2011		4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)
6. ISSUED BY American Embassy Baghdad Iraq			7. ADMINISTERED BY (If other than Item 6) CODE		
8. NAME AND ADDRESS OF CONTRACTOR (NO., street, city, county, State, and ZIP Code)				9a. AMENDMENT OF SOLICITATION NO. S-IZ100-11-R-0017	
				X 9b. DATED (SEE ITEM 11) 03/09/2011	
				10a. MODIFICATION OF CONTRACT/ORDER NO.	
				10b. DATED (SEE ITEM 13)	
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning ___1___ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.					
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.					
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b)					
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:					
X D. OTHER (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return ___ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)					
The purpose of this amendment is to: <ol style="list-style-type: none"> 1) extend the deadline for submissions from 12:00 on April 03, 2011 to 12:00 on April 10, 2011. 2) to include corrections to the Scope of work as per addendum 1. 3) Site plan will be handed to interested bidders upon request. 					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME OF CONTRACTING OFFICER Otis L Harrison		
15B. NAME OF CONTRACTOR/OFFEROR BY _____ (Signature of person authorized to sign)		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY  (Signature of Contracting Officer)		16C. DATE SIGNED 3/27/30 11

ADDENDUM 1

Section d. 02584 i: Quantities incorrect & no longer applies, contractor to use the schematic quantities provided

Section d. 02584 iii : Statement "Use manufactured long sweep bends with minimum radius of 7.5m, both horizontal and vertically, at other locations" to be deleted, it does not apply to this type of project.

Section d. 02584 ix: Only one hand hole (not 3) to have the NEMA 4 junction box. Successful contractor to be given the box location.

Section e. 02582 ii: New pole quantity is 20, not 21.

Exhibit G: Does not apply to the new poles. The poles come with 4 galvanized anchor bolts. Each anchor bolt is provided with 2 washers and 2 nuts. Poles also come with Masonite mounting template.

Exhibit B: Delete the reference to concrete encasement. Each 2" PVC conduit shall be direct buried 610mm below grade, with 310mm compacted sand and warning tape over the conduit set at 150mm below grade then covered with compacted soil.

The final locations for the hand holes and fixtures will be given to the successful contractor prior to mobilizing.

The conduit tie-in points have been identified on the diagrammatic drawing along with distances between poles.

Drawing
(will be handed to interested bidders upon request)