

Questions & Answers

Solicitation# SIZ10015Q0086

Solicitation Title: ECP6 Utility Power Connection

Q1: IS THERE A MAIN CIRCUIT BREAKER? IF SO, WHERE IS IT?

A1: NO THERE IS NOT AND THE SUCCESSFUL CONTRACTOR WILL NEED TO INSTALL ONE AS PER SOW AND IGE-4B.


Q2: WHAT'S THE DEPTH OF DIGGING REQUIRED?

A2: AS PER OBO SPECS 16120 CONDUCTORS AND CABLES NOT LESS THAN 70CM.

Q3: HOW MUCH IS THE DISTANCE BETWEEN THE UTILITY POWER AND THE GENERATORS?

A3: THE CABLE LENGTH IS APPROXIMATELY 130 – 150 METER DEPEND ON THE CABLE ROUTE THE SUCCESSFUL CONTRACTOR IS GOING TO USE.

John Gage



Contracting Officer