


| | | | | | |
|---|--|---|---|--|------------------------------------|
| AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT | | 1. CONTRACT ID CODE | | PAGE OF PAGES 1 2 | |
| 2. AMENDMENT/MODIFICATION NO. A002 | | 3. EFFECTIVE DATE SEE 16C | | 4. REQUISITION/PURCHASE REQ. NO. | |
| 5. PROJECT NO. (If applicable) | | 6. ISSUED BY Contracting and Procurement Section General Services Office American Embassy Manila, Seafront Compound, Pasay City | | 7. ADMINISTERED BY (If other than Item 6) CODE | |
| 8. NAME AND ADDRESS OF CONTRACTOR (NO., street, city, county, State, and ZIP Code) | | 9a. AMENDMENT OF SOLICITATION NO. SRP380-13-Q-0061 | | 9b. DATED (SEE ITEM 11) July 02, 2013 | |
| | | 10a. MODIFICATION OF CONTRACT/ORDER NO. | | 10b. DATED (SEE ITEM 13) | |
| 11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS | | | | | |
| <p><input type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input type="checkbox"/> is not extended</p> <p>Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers.</p> <p>FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.</p> | | | | | |
| 12. ACCOUNTING AND APPROPRIATION DATA (If required) | | | | | |
| 13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14. | | | | | |
| A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A. | | | | | |
| B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b) | | | | | |
| C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF: | | | | | |
| D. OTHER (Specify type of modification and authority) | | | | | |
| E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return 1 copy to the issuing office. | | | | | |
| 14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) RFQ NO. SRP380-13-Q-0061, Asphalt Paving/Repair services at Chancery Compound The purpose of this amendment is to reflect the following changes: (1) On Attachment #4, Page 2, under Section I (List of Attachments), revise paragraph 1 of Part 2.4.1, to read as follows: <p style="text-align: center;"><i>See next page</i></p> | | | | | |
| Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect. | | | | | |
| 15A. NAME AND TITLE OF SIGNER (Type or print) | | | 16A. NAME OF CONTRACTING OFFICER NENITA V. WHITAKER | | |
| 15B. NAME OF CONTRACTOR/OFFEROR BY _____ (Signature of person authorized to sign) | | 15C. DATE SIGNED | 16B. UNITED STATES OF AMERICA BY  (Signature of Contracting Officer) | | 16C. DATE SIGNED 7/16/13 |

| | | |
|--------------------|---|---------------------------------|
| CONTINUATION SHEET | REFERENCE NO. OF DOCUMENT BEING CONTINUED RFQ No. SRP380- 13-Q-0061 | PAGE 2 of 2 Pages |
| NAME OF CONTRACTOR | | |

Continued--

“General: As soon as the hot-mix paving has been layed, begin compaction using Tandem Roller. Compact hot-mix paving with hot, hand tampers or vibratory-plate compactors in areas inaccessible to rollers. Complete compaction before mix temperature cools to 185 deg F (85 deg C).”

- (2) The revised page 2 of Attachment #4, Section I (List of Attachments), is amended.
- (3) Replace existing page with the attached revised page 2 of Attachment #4.
- (4) The submission date of proposals is hereby extended to July 23, 2013, no later than 4:00 p.m.
- (5) All other terms and conditions remain unchanged and in full force and effect.

course to required grade, cross section, and thickness when compacted. Spread mix at minimum temperature of 250 deg F (121 deg C). Regulate paver machine speed to obtain smooth, continuous surface free of pulls and tears in asphalt-paving mat. Place paving in consecutive strips not less than 10 feet (3 m) wide unless infill edge strips of a lesser width are required. Promptly correct surface irregularities in paving course behind paver. Use suitable hand tools to remove excess material forming high spots. Fill depressions with hot-mix asphalt to prevent segregation of mix; use suitable hand tools to smooth surface.

2.4 COMPACTION

- 2.4.1 **General:** *As soon as the hot-mix paving has been laid, begin compaction using Tandem Roller. Compact hot-mix paving with hot, hand tampers or vibratory-plate compactors in areas inaccessible to rollers. Complete compaction before mix temperature cools to 185 deg F (85 deg C).*

NOVA

Breakdown Rolling: Complete breakdown or initial rolling immediately after rolling joints and outside edge. Examine surface immediately after breakdown rolling for indicated crown, grade, and smoothness. Correct lay down and rolling operations to comply with requirements.

Intermediate Rolling: Begin intermediate rolling immediately after breakdown rolling while hot-mix asphalt is still hot enough to achieve specified density. Continue rolling until hot-mix asphalt course has been uniformly compacted to the following density:

Average Density: 92 percent of reference maximum theoretical density according to ASTM D 2041, but not less than 90 percent nor greater than 96 percent. The Contractor shall conduct two (2) test holes to determine actual density of asphalt.

Finish Rolling: Finish roll paved surfaces to remove roller marks while hot-mix asphalt is still warm.

Erect barricades to protect paving from traffic until mixture has cooled enough not to become marked.

2.5 INSTALLATION TOLERANCES

- 2.5.1 **Thickness:** Compact each course to produce the thickness indicated within the following tolerances:

Base Course: Plus or minus 1/2 inch (13 mm).

Surface Course: Plus 1/4 inch (6 mm), no minus.

- 2.5.2 **Surface Smoothness:** Compact each course to produce a surface smoothness within the following tolerances as determined by using a 10-foot (3-m) straightedge applied transversely or longitudinally to paved areas:

Base Course: 1/4 inch (6 mm).

Surface Course: 1/8 inch (3 mm).

Crowned Surfaces: Test with crowned template centered and at right angle to crown. Maximum allowable variance from template is 1/4 inch (6 mm).