



To : Offerors
From : Mike M. Pitts, Contracting Officer *MP*
Date : August 7, 2013

Subject: Answers to the Questions asked by different Offerors for “Security Upgrade of FM Building and Commissary, Islamabad” Solicitation # SPK330-13-Q-5692 during and after site visit held on August 05, 2013.

Q.1) Is there any other brand or company who provides Aluminum door hinges locally for steel doors?

Ans) Hinges are one of the critical items in these doors. They are American brand. Please see answer of Q. 2.

Q.2) Can you provide the brand name and product number (part number) of the “US made Hinges” and “Push bar lock” for steel doors that SOW requires to use?

Ans) Roton 780-112HD Heavy Duty Concealed Leaf Continuous Hinge. LockeyUSA PB1100 Fire Rated 36" Panic Exit Touch Bar. Sentry Safety 9036 Commercial Door Closer CS, LS, BC, AS, DA, #6 Capable of handling doors with weights from 300 lbs

Q.3) A proposal which does not include the usage of US made hinges, will it be acceptable?

Ans) No.