

QUESTIONS & ANSWERS
SITE VISIT – Repair floor at MSG Quarters
SOLICITATION SPM07013Q0042

1. **There will be an opening between the socles and the new vinyl floor tiles. Is a joining compound required to close this opening?**

Answer: Yes, close gap between wooden socles and new floor (1/8") tiles with Sika construction joining compound.