

QUESTIONS & ANSWERS
SITE VISIT – Repair WHSE Receiving Area
SOLICITATION SPM07016Q0025

1. How much area of the curb must be demolished?

Answer: Four (4) Feet

2. What happens to the light pole in that area?

Answer: Leave where it is.

3. What is the slope for the new staging area?

Answer: Use existing sidewalk slope