

AMENDMENT OF SOLICITATION			1. CONTRACT ID CODE		PAGE OF PAGES 1/2	
2. AMENDMENT NO. A001		3. EFFECTIVE DATE 6/1/2016		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable) N/A
6. ISSUED BY CODE			7. ADMINISTERED BY (If other than Item 6) CODE			
Department of State - American Embassy - Asunción JOINT ADMINISTRATIVE ORGANIZATION GENERAL SERVICES OFFICE 1776 Mcal. López Ave. Asunción - Paraguay			Same a block #6			
8. NAME AND ADDRESS OF CONTRACTOR (NO., street, city, county, State, and ZIP Code)				9a. AMENDMENT OF SOLICITATION NO. SPA10016Q0011		
				9b. DATED (SEE ITEM 11) 5/10/2016		
				10a. MODIFICATION OF CONTRACT/ORDER NO.		
				10b. DATED (SEE ITEM 13)		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. <b>FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.</b> If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.						
12. ACCOUNTING AND APPROPRIATION DATA (If required)						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.						
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b)						
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
<input checked="" type="checkbox"/> D. OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment is to (a) extend the Offers due date from June 2 <sup>nd</sup> . 2016 to June 9 <sup>th</sup> 2016, and (b) update the Statement Of Work (SOW) as further described in the attached page. Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME OF CONTRACTING OFFICER		
				Sharla Magana, CO		
15B. NAME OF CONTRACTOR/OFFEROR		15C. DATE SIGNED	16B. UNITED STATES OF AMERICA		16C. DATE SIGNED	
BY _____ (Signature of person authorized to sign)			BY  (Signature of Contracting Officer)		6/1/16	

**This Solicitation is amended as follows:**

1. STANDARD FORM 1442, SOLICITATION, OFFER AND AWARD. BLOCK 13 ADDITIONAL SOLICITATION REQUIREMENTS shall read:

A. Sealed offers in original and 2 copies to perform the work required are due at the place specified in Item 8 by **5:00pm** (hour) local time **06/09/16** (date). Sealed envelopes containing offers shall be marked to show the offeror's name and address, the solicitation number, and the date and time offers are due.

2. Replace the table in paragraph A. PRICE and first paragraph and table in **Attachment #6** entirety.

**CAC 1 inner gate:**

Ten (10) wires x 4 mm2 from the green box to Post one  
Four (4) wires x 4 mm2 will be needed from the green box to a micro switch in the gate booth.

**CAC 2 inner gate**

Ten (10) wires x 4 mm2 from the green box to Post one  
Four (4) wires x 4 mm2 will be needed from the green box to a micro switch in the gate booth.

**CAC 2 outer gate**

Ten (10) wires x 4 mm2 from the green box to Post one  
Four (4) wires x 4 mm2 will be needed from the green box to a micro switch in the gate booth.

**CAC 3 inner gate**

Ten (10) wires x 4 mm2 from the green box to Post one  
Four (4) wires x 4 mm2 will be needed from the green box to a micro switch in the gate booth.

**Remarks:** locally available wires NYY or similar acceptable for all work described in paragraphs CAC 1, CAC 2 and CAC 3 above.

Conduits: Underground installation of polyethylene conduits (water use) will be acceptable 4" diameter – in all cases there must be a 75% free space after the new wire installation. Galvanized conduits may be installed along the walls, no for underground use. Conduits must be at least 60 cm deep in all cases

General: contractors must minimize the disruptions in their proposals. All areas should be left in the same condition those were before the construction began (to be documented in pictures with contractor). Contractor may need to provide services on weekends including Sundays and night in order to minimize the disruptions to embassy operations. Maximum distance between manholes should be 30 m

Except as provided herein, all terms and conditions of the document referenced in Item 9a of form SF30 as heretofore changed, remains unchanged and in full force and effect.

\*\*\*\*NOTHING FOLLOWS \*\*\*\*