

EMBASSY OF THE UNITED STATES OF AMERICA  
PRAIA, CAPE VERDE

REQUEST FOR QUOTATIONS  
(RFQ) NUMBER *SCV-11-Q-0236*  
Date: April 21, 2011

***GENERATOR PURCHASE AND INSTALLATION***

The US Embassy has a requirement for the purchase and installation of a 20 – 25KVA generator. If you would like to submit a quotation, please contact Tracci Gabel, Contracting Officer at ***2608913*** for complete details.

The U.S. Government intends to award a contract/purchase order to the responsible company submitting an acceptable quotation at the lowest price. We intend to award a contract/purchase order based on initial quotations, without holding discussions, although we may hold discussions with companies in the competitive range if there is a need to do so.

Quotations are due by ***12:00 on Wednesday May 4, 2011.***



REQUEST FOR QUOTATIONS  
(RFQ) NUMBER *SCV-11-Q-0236*

Section 1 - The Schedule

- Schedule Of Supplies/Services, Block 20 Description/Specifications/Work Statement,
- Required Delivery Dates
- Item Pricing

Section 2 - Contract Clauses

- Contract Clauses
- Addendum to Contract Clauses - FAR and DOSAR Clauses not Prescribed in Part 12
- Section 3 - Solicitation Provisions
- Solicitation Provisions
- Addendum to Solicitation Provisions - FAR and DOSAR Provisions not Prescribed in Part 12

Section 4 - Evaluation Factors

- Evaluation Factors
- Addendum to Evaluation Factors - FAR and DOSAR Provisions not Prescribed in Part 12

Section 5 - Offeror Representations and Certifications

- Offeror Representations and Certifications
- Addendum to Offeror Representations and Certifications - FAR and DOSAR Provisions not Prescribed in Part 12

Section 6 - Proposal Preparation Instructions

EMBASSY OF THE UNITED STATES OF AMERICA  
PRAIA, CAPE VERDE

REQUEST FOR QUOTATIONS  
(RFQ) NUMBER *SCV-11-Q-0236*

SECTION 1 - THE SCHEDULE\*\*

SCHEDULE OF SUPPLIES/SERVICES (Block 20) DESCRIPTION/SPECIFICATIONS/WORK STATEMENT

1.0 GENERAL

The purpose of this procurement is to expediently obtain critical power equipment, in order to support American Embassy Praia. This solicitation, at the quoter's option, allows two delivery dates. The first date is an essential requirement of this procurement, available equipment shall be delivered to the transportation point no later than **5** days after the date of the order. The quoter may (at its option) additionally offer the Government equipment which is not available in five days but will be available no later than **30** calendar days after the date of order. The quoter shall include, in the offer/quotation, the cost of transportation to: *Palmarejo, Praia, Cape Verde*.

1.1. DESCRIPTION

1.1.1 Provide one 20 - 25KVA prime power rated engine generator set, including: prime power, directly coupled shaft, engine generator sets. The unit shall be configured to consist of a liquid cooled engine and a conventional alternator and an electronic governor. The unit shall be manufactured complete with system controls and all necessary accessories to make the genset fully operational. All equipment shall be as specified but shall not be limited to the items specified herein.

1.1.2 Provide for integral automatic and manual operation from the selector switch: (1) automatic transfer switch (ATS) for the generator as described elsewhere in this specification. The system shall come on-line fully automatically, and on restoration of utility automatically re-transfers load to normal power, shuts down the generator and returns to readiness for another operating cycle. (2) Provision shall be made on the switch for a manual operation using the selector switch in the MANUAL position.

1.1.3 Prime and overload ratings shall meet requirements herein.

1.1.4 Provide a three-position selector switch, as required in 2.3.2.

\*\*The complete solicitation will be given upon request to the Contracting Officer.

## 1.2. REQUIREMENTS

1.2.1 The electric generating system consists of a prime mover, generator, electronic governor, couplings, and all controls, tested as a complete unit.

1.2.2 Conform to NFPA 70 and applicable inspection authorities.

1.2.3 Transfer switches shall be labeled under UL 1008.

## 1.3 SUMMARY OF EQUIPMENT

1.3.1 Prime Power Rated Engine Generator, 22kVA.

1.3.2 Automatic Transfer Switch (ATS).

1.3.3 Sound-attenuated, weatherproof enclosure.

Generator output power characteristics shall be 220/380, 50HZ, 3-phase and neutral, (4 Wire) except where otherwise stated.

## 2.0 ENGINE-GENERATOR SET

### 2.1 ENGINE

The prime mover shall be a liquid cooled, diesel fuel, naturally aspirated engine of 4-cycle design, with four cylinders (min).

2.1.2 The engine shall be cooled with an integral, unit mounted radiator, fan, water pump, and closed coolant recovery system, which provides visual diagnostic means to determine if the system is operating with a normal engine coolant level. The radiator shall be designed for satisfactory operation in 110 Degrees Fahrenheit (44 degrees Celsius) ambient temperature.

2.1.3 The intake air filter (with replaceable element) shall be mounted on the unit. Full pressure lubrication shall be supplied by a positive displacement lube-oil pump. The engine shall have a replaceable oil filter with internal bypass and replaceable elements. Engine coolant and oil drain extension must be provided to outside the mounting base for cleaner and convenient engine servicing. A fan guard shall be installed for personnel safety.

2.1.4 The engine shall have a battery charging DC alternator with a transistorized voltage regulator. Remote 2-wire electric starting shall be accomplished by a solenoid shift electric starter.

2.1.5 Engine speed electronic governor shall have a frequency control, adjustable from zero to five percent droop, to maintain alternator frequency within five percent (across the range) from no load to full load. Steady state regulation shall be within plus or minus 0.33 percent.

2.1.6 The engine fuel system shall be designed for operation using No. 2 diesel fuel. A secondary fuel filter, water separator with glass bowl, manual fuel printing pump and fuel shut-off solenoid and all piping shall be installed on the unit.

2.1.7 Sensors shall be located on the engine for: low oil pressure shutdown, high coolant temperature shutdown, low coolant level shutdown, overspeed shutdown, and overcrank shutdown. These sensors shall be connected to the control panel using a wiring harness with the following features: wire number labeling on each end of the wire run for ease of identification, a molded rubber boot to cover the electrical connection on each sensor to prevent corrosion and all wiring to be run in flexible conduit for mechanical protection and environmental protection.

2.1.8 The electric jacket-coolant heater shall be thermostatically controlled to automatically maintain the coolant within plus or minus 3 degrees of the control temperature. The control temperature shall be the temperature recommended by the manufacturer to optimize the starting time.

2.1.9 Definitions - The following definitions apply for the purpose of this procurement and any resulting contract:

Continuous Load - A load in which maximum current is anticipated for three hours or more in accordance with the continuous duty cycle, as defined by NFPA-70. Continuous Duty Rating - A duty rating, equivalent to a load equal to one hundred percent of the genset nameplate rating for a duration of more than three hours.

Prime Rating - A duty rating, equivalent to seventy percent of the genset nameplate rating, for a continuous period of 12 hours. A prime rated generator is required to safely support the load, in the absence of city power, for an indefinite period. While it is recognized that over a 24 hour, operational load cycle, period the load variation may be considerable, this rating permits the maximum continuous load and duration to be addressed in the genset selection process.

Overload Rating - This is defined as satisfactory operation at a load of 110 percent of the nameplate rating, for a period of two hours.

## 2.2 ALTERNATOR

2.2.1 The alternator shall be a multi-pole revolving field type, wired for 220/380v, 3-phase, 50 HZ, 4 wire, with a brushless, static exciter. Generators shall be prime rated. The stator shall be directly connected to the engine flywheel to ensure permanent alignment. The generator shall meet temperature rise standards for class "F" varnish and conform to MIL-I-24092, Type "M" class 155. All leads shall be extended into the AC connected panel. The alternator shall be protected by internal thermal overload protection and an automatic reset field circuit breaker. One step load acceptance shall be 100% of nameplate kW rating and the generator shall return to normal operation within 15 seconds.

2.2.2 The engine-generator set shall be so designed that voltage dip upon application of nameplate full load shall not exceed 30% with recovery to stable operation within 15 seconds.

2.2.3 The solid state voltage regulator shall control output voltage by varying the exciter magnetic field to provide plus or minus 1% regulation during stable load conditions. The regulator shall have a voltage droop characteristic of 4 volts per cycle to maximize motor starting capability in the event an extremely heavy load drops the output frequency. The frequency at which this droop operation begins shall be adjustable allowing the generator set to be properly matched to the load characteristics ensuring optimum system performance.

2.2.4 The voltage regulator shall contain a limiting circuit to prevent output voltage surges in excess of 110% of rated voltage during generator set operation. On a loss of the sensing signal, the voltage regulator shall shutdown to prevent an overvoltage condition from occurring. A voltage regulator that can go into a full field condition is unacceptable. LED indication will be provided on the regulator to monitor the sensing (yellow), excitation (green), and output circuit (red). A rheostat shall provide a minimum of plus or minus 10% voltage adjustment from the rated value.

2.2.5 The engine generator set shall be mounted with vibration isolators on a welded steel base, which shall permit suitable mounting to any level surface.

## 2.3 GENERATOR CONTROLS

2.3.1 All engine, alternator controls and instrumentation shall be designed, built, wired, tested and shock mounted in a NEMA 1 enclosure to the engine-generator set by the manufacturer. It shall contain D.C. panel lighting and a fused circuit to protect the controls.

2.3.2 The engine-generator set shall contain a complete engine start-stop control, which starts the engine on closing contacts and stops the engine on opening contacts. An automatic preheat circuit that can also be operated in a manual mode shall be provided. A cyclic cranking limiter shall be provided to open the starting circuit, after eight attempts, if the engine has not started. Engine control modules shall be solid state plug-in type for high reliability and easy service. The engine controls shall also include a 3-position selector switch with the following positions: OFF/MANUAL/AUTO. A red annunciator lamp shall be energized when the switch is not in the automatic position.

2.3.3 Safety shutdown monitoring system shall include solid state engine monitor with individual lights and one common external alarm contact indicating the following conditions: Overcrank shutdown, Overspeed shutdown, High Coolant Temperature (Low Coolant Level shutdown), Low Oil Pressure shutdown, and fuel leak. Monitoring system shall include lamp test switch for manual reset of tripped conditions. Engine RPM shall be monitored by an independent permanent magnetic sensor. The engine shall shutdown immediately and energize a LOSS-OF-RPM shutdown light in the event of a failure.

2.3.4 Engine instrumentation shall consist of an oil pressure gauge, coolant temperature gauge, D.C. ammeter and an engine run-hour-meter, located on the unit control panel. Alternator instrumentation shall include analog meters to indicate output voltage per phase; amperage per phase and generator output frequency.

2.3.5 A red light (labeled using silk screened black letters on the control panel), which becomes energized when a low fuel level is sensed in the base mounted tank.

2.3.6 A thermal-magnetic, UL listed, main-line, molded case circuit breaker shall be mounted in the generator terminal panel. Line side connections shall be made at the factory. A system utilizing a manual reset field circuit breaker and current transformers is unacceptable.

2.3.7 A red emergency stop pushbutton shall be provided on the exterior of the enclosure and shall be accessible without the use of a key and without having to open the enclosure.

## 2.4 MISCELLANEOUS EQUIPMENT

2.4.1 The following miscellaneous equipment shall be provided as a part of this procurement action:

2.4.1.1 A sound attenuating weatherproof enclosure: The engine-generator set shall be factory enclosed in a 12 gauge steel enclosure constructed with corner posts, coated with electrostatically applied zinc and finished with baked enamel paint. The installed equipment sound levels shall be no more than 95 db at 3 meters (maximum) when the unit is operated at full load, under rated ambient conditions. The enclosure shall have large, hinged doors to allow complete access to the engine, alternator and control panel. Each door shall be fitted with stainless steel, lockable hardware with two sets of identical keys. The enclosure shall come equipped with a heater for the prevention of condensation within the enclosure.

2.4.1.2 An automatic dual rate battery charger mounted inside the genset enclosure, in its own cabinet, shall be provided. The automatic equalizer system shall monitor and limit the charge current to 10 amps. The output voltage is to be determined by the charge current rate. The charger shall have a maximum open circuit voltage of 35 volts and be protected against a reverse polarity connection.

2.4.1.3 A heavy duty, lead acid battery set shall be provided by the generator set manufacturer of adequate voltage and amperage capacity to start and operate the engine. Provide all intercell and connecting battery cables as required for complete installation. The battery shall be shipped in place fully charged with electrolyte.

2.4.1.4 The genset parts shall be warranted by the offeror in accordance with the terms of this contract.

2.4.1.5 An integral skid type fuel tank shall be provided with the generator set to permit 18-24 hours of operation at full rated load. The fuel tank shall be a dual wall or banded tank with a retention capacity of 110% of the internal tank. The integral fuel tank shall include an interstitial leak detector to provide notification of the presence of fuel in the interstitial space. The leak detector shall be able to be wired to the safety shutdown monitoring system and shall have a dedicated indicator light.

## 3.0 AUTOMATIC TRANSFER SWITCH (ATS)

### 3.1 GENERAL

3.1.1 The automatic transfer switch shall be furnished so as to maintain system compatibility and local service responsibility for the complete emergency power system. It shall be listed by Underwriter's Laboratory, Standard 1008, with circuit breaker protection afforded by the generator breaker. Representative production samples of the transfer switch, which have been demonstrated through tests, shall withstand 10,000 mechanical operation cycles (min) without failure. One operation cycle is the electrically operated transfer from normal to emergency and back to normal. Wiring shall comply with NEC table 373-6. The manufacturer shall furnish complete schematic and wiring diagrams for the particular automatic transfer switch and a typical wiring diagram for the entire system showing all components, relays and part numbers. This ATS shall be an integral part of the generator set and be secured to the winterized enclosure. All wiring and connections to integrate the ATS into the generator output shall be made by the vendor before acceptance by the Government.

### 3.2 ATS RATINGS & PERFORMANCE

3.2.1 The automatic transfer switch (ATS) shall be a 3-pole design, rated for full load, continuous operation. The ATS rating shall be ambient temperatures of -15 Degrees Celsius to +40 Degrees Celsius. Main power switch contact shall be rated to operate at 380/ 220 volts maximum unless otherwise specified herein. The transfer switch shall have a minimum withstand and closing rating of 42,000 amperes. The RMS symmetrical fault current ratings shall be the rating listed in the UL listing or component recognition procedures for the transfer switch.

### 3.3 ATS CONSTRUCTION

3.3.1 The transfer switch shall be double throw construction, positively electrically and mechanically interlocked to prevent simultaneous closing and mechanically held in both normal and emergency positions. Independent break before make action shall be used as protection to prevent dangerous source to source connections. The transfer switch shall be approved for manual operation. The electrical operating means shall be approved for manual operation. The electrical operating means shall be by electric solenoid. Every portion of the contactor is to be positively mechanically connected. No clutch or friction drive mechanism is allowed, and parts are to be kept to a minimum. This transfer switch shall not contain integral overcurrent devices in the main power circuit, including molded case circuit breakers or fuses.

3.3.2 The transfer switch electrical actuator shall have an independent disconnect means to disable the electrical operation during manual switching. Maximum electrical transfer time in either direction shall be 160 milliseconds, exclusive of time delays. Main switch contacts shall be high pressure silver alloy contacts to resist burning and pitting for long life operation.

3.3.3 There shall be one Single Pole Double Throw, 10 ampere, 250 volt auxiliary contact on both normal and emergency sides, operated by the transfer switch. Full rated neutral bar with lugs for normal, emergency and load conductors shall be provided inside the cabinet.

### 3.4 CONTROL EQUIPMENT

3.4.1 All control equipment shall be mounted on the inside of the cabinet door in a metal lockable enclosure with transparent safety shield to protect all solid state circuit boards. This will allow for ease of service access when main cabinet lockable door is open, but prevent access by unauthorized personnel. Control boards shall have installed cover plates to avoid shock hazard while making control adjustments. The solid state voltage sensors and time delay modules shall be plug-in circuit boards with silver or gold contacts for ease of service.

3.4.2 A solid state under-voltage sensor shall monitor each phase of the normal source and provide adjustable ranges for field adjustments for specific applications needs. Pick-up and drop-out settings shall be adjustable from a minimum of 70% to a maximum of 95% of nominal voltage. The utility input voltage shall be stepped down to 24VAC for safety and reliability.

3.4.3 Signal the engine-generator set to start in the event of a power interruption. A set of contacts shall close to start the engine and open for engine shutdown. An adjustable, solid state time delay start (1 to 180 seconds) shall delay this signal to avoid nuisance start-ups on momentary voltage dips or power outages.

3.4.4 Transfer the load to the engine-generator set after it reaches proper voltage (80%) and frequency (80%). A solid state time delay (30 seconds) shall delay this transfer to allow the engine-generator to warm-up before application of load. There shall be a switch to bypass this warm-up timer when immediate transfer is required.

3.4.5 Retransfer the load to the line after normal power restoration. A return to utility timer (5-10 minutes) shall delay this transfer to avoid short term normal power restoration.

3.4.6 The operating power for transfer and retransfer shall be obtained from the source to which the load is being transferred. Controls shall provide an automatic retransfer of the load from emergency to normal if the emergency source fails with the normal source available.

3.4.7 Signal the engine-generator to stop after the load re-transfers to normal. An adjustable, solid state engine cool-down timer (3-10 minutes) shall permit the engine to run unloaded to cool-down before shutdown.

3.4.8 Provide an engine minimum run timer (10 minutes) to ensure an adequate engine run period.

3.4.9 Provide a solid state plant exercise clock to set the day and time of generator set exercise period. Clock shall have a seven days, 24 hour programmable clock powered from the load side of the transfer switch. A 150 hour internal battery shall be supplied to maintain the circuit board settings when the load side of the transfer switch is de-energized. Include a switch to select if the load will transfer to the engine-generator set during the exercise period.

3.4.10 The transfer switch shall have a time delay neutral feature to provide a time delay (5 seconds) during the transfer in either direction during which time the load is isolated from both power sources. This allows residual voltage components of motors or other conductive loads (such

as transformers) to decay before completing the switching cycle. A switch will be provided to bypass this feature when immediate transfer is required.

3.4.11 Front mounted controls shall include a selector switch to provide for a NORMAL TEST mode with full use of time delays, FAST TEST mode which bypasses all time delays to allow for testing the entire system in less than one minute, or AUTOMATIC mode to set the system for normal operation.

3.4.12 Provide colored indicator lamps to be energized when the transfer switch position is in either UTILITY (white) or EMERGENCY (red). A third lamp shall be provided to indicate STANDBY OPERATING (amber). These lights shall be energized from utility or the engine-generator set.

3.4.13 Provide manual operating handle to allow for manual transfer. This handle shall be mounted inside the lockable enclosure so accessible only by authorized personnel.

3.4.14 Provide a safety disconnect switch to prevent load transfer and automatic engine start while performing maintenance. This switch will also be used for manual transfer switch operation.

3.4.15 Provide LED status lights to give a visual readout of the operating sequence. This shall include: utility on, engine warm up, engine warm up bypass, standby voltage "ready", standby frequency "ready", standby on, transfer to standby, return to utility, engine cool-down, engine minimum run and fast test mode.

### 3.5 MISCELLANEOUS ATS EQUIPMENT

3.5.1 The transfer switch mechanism and controls shall be mounted in a NEMA 1 enclosure, rated for indoor installations or a NEMA 3R enclosure for outdoor installation as required for the installation.

## 4.0 MISCELLANEOUS

### 4.1 FACTORY TESTING

4.1.1 Before shipment of the equipment, the engine-generator set shall be tested under rated load and power factor for performance and proper fronting of control and interfacing circuits. Tests shall include:

4.1.1.1 Verifying all safety shutdowns and components are functioning properly.

4.1.1.2 Single step load pick-up per NFPA 110-1985, Paragraph 5-13.2.6.

4.1.1.3 Transient and voltage dip responses and steady state voltage and speed (frequency) checks.

4.1.1.4 The factory test data sheet shall identify all tests (PASSED or FAILED) and accompany each generator set. This will be reviewed by the DOSREP before written acceptance is provided.

## 4.2 OWNERS MANUALS

4.2.1 Two (2) hard copy sets of owner's manuals specific to the genset and products supplied shall be located inside each unit and accompany the equipment. General operating instruction, preventive maintenance, wiring diagrams, schematics and parts exploded views specific to this model shall be included. A .pdf version of the owner's manuals shall also be provided on a compact disc for shipped with each generator.

## 4.3 SUBMITTALS

4.3.1 Provide two complete sets (for each rating of machine) of Engineering Submittal for approval, prior to production release, showing all components, in addition to the engine, generator and automatic transfer switch. Submittals shall include complete system interconnection wiring diagrams and manufacturer's warranty form indicating compliance with these specifications.

## 4.4 SPARES

A 2000 hours spare parts kit shall be provided for each genset supplied under this contract. The offer shall include a complete list of all vendors recommended spares. The offer shall explicitly identify each Table I line item by packaged dimensions, weight and price.

## 4.5 WARRANTY

The offeror shall provide a one-year warranty on parts, which starts from the date the equipment is commissioned on-site. This requirement shall not modify or change the standard contract warranty agreement.

## 4.6 DELIVERY

The generator sets, transfer switches, spare parts and trailers are being imported duty free under the diplomatic duty free status of the American Embassy, the goods will be considered delivered once received and inspected by the Receiving Officer at the United States Embassy, Praia.

## SECTION 2 - CONTRACT CLAUSES

52.204-9 – PERSONAL IDENTIFICATION VERIFICATION OF CONTRACTOR PERSONNEL (SEPT 2007)

FAR 52.212-4 CONTRACT TERMS AND CONDITIONS – COMMERCIAL ITEMS (JUN 2010), is incorporated by reference. (See SF-1449, block 27a).

FAR 52.212-5 CONTRACT TERMS AND CONDITIONS REQUIRED TO IMPLEMENT STATUTES OR EXECUTIVE ORDERS – COMMERCIAL ITEMS (OCT 2010)

As prescribed in [12.301](#)(b)(4), insert the following clause:

CONTRACT TERMS AND CONDITIONS REQUIRED TO IMPLEMENT STATUTES OR EXECUTIVE ORDERS—  
COMMERCIAL ITEMS (OCT 2010)

(a) The Contractor shall comply with the following Federal Acquisition Regulation (FAR) clauses, which are incorporated in this contract by reference, to implement provisions of law or Executive orders applicable to acquisitions of commercial items:

- (1) [52.222-50](#), Combating Trafficking in Persons (Feb 2009) ([22 U.S.C. 7104\(g\)](#)).  
[ ] Alternate I (Aug 2007) of [52.222-50](#) ([22 U.S.C. 7104\(g\)](#)).
- (2) [52.233-3](#), Protest After Award (AUG 1996) ([31 U.S.C. 3553](#)).
- (3) [52.233-4](#), Applicable Law for Breach of Contract Claim (OCT 2004) (Pub. L. 108-77, 108-78)

(b) The Contractor shall comply with the FAR clauses in this paragraph (b) that the Contracting Officer has indicated as being incorporated in this contract by reference to implement provisions of law or Executive orders applicable to acquisitions of commercial items:

[ ] (1) [52.203-6](#), Restrictions on Subcontractor Sales to the Government (Sept 2006), with Alternate I (Oct 1995) ([41 U.S.C. 253g](#) and [10 U.S.C. 2402](#)).

[ ] (2) [52.203-13](#), Contractor Code of Business Ethics and Conduct (APR 2010) (Pub. L. 110-252, Title VI, Chapter 1 ([41 U.S.C. 251 note](#))).

[ ] (3) [52.203-15](#), Whistleblower Protections under the American Recovery and Reinvestment Act of 2009 (June 2010) (Section 1553 of Pub. L. 111-5). (Applies to contracts funded by the American Recovery and Reinvestment Act of 2009.)

[ ] (4) [52.204-10](#), Reporting Executive Compensation and First-Tier Subcontract Awards (JUL 2010) (Pub L. 109-282)(31 USC 6101 note)

[ ] (5) – (20) Reserved

[ X ] (21) [52.222-19](#), Child Labor—Cooperation with Authorities and Remedies (JUL 2010) (E.O. 13126).

[ ] (22) [52.222-21](#), Prohibition of Segregated Facilities (Feb 1999).

[ ] (23) [52.222-26](#), Equal Opportunity (Mar 2007) (E.O. 11246).

[ ] (24) [52.222-35](#), Equal Opportunity for Special Disabled Veterans, Veterans of the Vietnam Era, and Other Eligible Veterans (Sept 2006) ([38 U.S.C. 4212](#))

[ ] (25) [52.222-36](#), Affirmative Action for Workers with Disabilities (OCT 2010) ([29 U.S.C. 793](#)).

[ ] (26) [52.222-37](#), Employment Reports on Special Disabled Veterans, Veterans of the Vietnam Era, and Other Eligible Veterans (Sept 2006) ([38 U.S.C. 4212](#))

[ ] (27) [52.222-54](#), Employment Eligibility Verification (JAN 2009). (Executive Order 12989). (Not applicable to the acquisition of commercially available off-the-shelf items or certain other types of commercial items as prescribed in [22.1803](#).)

[ ] (28) (i) [52.223-9](#), Estimate of Percentage of Recovered Material Content for EPA–Designated Items (May 2008) ([42 U.S.C. 6962\(c\)\(3\)\(A\)\(ii\)](#)). (Not applicable to the acquisition of commercially available off-the-shelf items

[ ] (ii) Alternate I (May 2008) of [52.223-9](#) ([42 U.S.C. 6962\(i\)\(2\)\(C\)](#)). (Not applicable to the acquisition of commercially available off-the-shelf items.)

[ x] (29) [52.223-15](#), Energy Efficiency in Energy-Consuming Products (DEC 2007) ([42 U.S.C. 8259b](#)).

[ ] (30) (i) [52.223-16](#), IEEE 1680 Standard for the Environmental Assessment of Personal Computer Products (Dec 2007) (E.O. 13423).

[ ] (ii) Alternate I (DEC 2007) of [52.223-16](#).

[ X ] (31) [52.223-18](#), Contractor Policy to Ban Text Messaging While Driving (SEP 2010) (E.O. 13513).

[ ] (32) Reserved

[ ] (33) (i) [52.225-3](#), Buy American Act—Free Trade Agreements—Israeli Trade Act (June 2009) (41 U.S.C. 10a-10d, 19 U.S.C. 3301 note, 19 U.S.C. 2112 note, Pub. L 108-77, 108-78, 108-286, 109-53 and 109-169).

[ ] (ii) Alternate I (Jan 2004) of [52.225-3](#).

[ ] (iii) Alternate II (Jan 2004) of [52.225-3](#).

[ ] (34) [52.225-5](#), Trade Agreements (AUG 2009) ([19 U.S.C. 2501](#), *et seq.*, [19 U.S.C. 3301](#) note).

[ X ] (35) [52.225-13](#), Restrictions on Certain Foreign Purchases (June 2008) (E.O.'s, proclamations, and statutes administered by the Office of Foreign Assets Control of the Department of the Treasury).

[ ] (36) – (37) Reserved

[ ] (38) [52.232-29](#), Terms for Financing of Purchases of Commercial Item (FEB 2002)(41 USC 255(f), 10 USC 2307(f))

[ ] (39) [52.232-30](#), Installation Payments of Commercial Item (OCT 1995) (41 USC 255(f), 10 USC 2307 (f))

[ ] (40) [52.232-33](#), Payment by Electronic Funds Transfer—Central Contractor Registration (Oct 2003) ([31 U.S.C. 3332](#)).

[ X] (41) [52.232-34](#), Payment by Electronic Funds Transfer—Other than Central Contractor Registration (MAY 1999) ([31 U.S.C. 3332](#)).

[ ] (42) - (43) Reserved

[ ] (44)(i) [52.247-64](#), Preference for Privately Owned U.S.-Flag Commercial Vessels (Feb 2006) ([46 U.S.C. Appx. 1241\(b\)](#) and [10 U.S.C. 2631](#)).

[ ] (ii) Alternate I (Apr 2003) of [52.247-64](#).

(c) Reserved

(d) *Comptroller General Examination of Record*. The Contractor shall comply with the provisions of this paragraph (d) if this contract was awarded using other than sealed bid, is in excess of the simplified acquisition threshold, and does not contain the clause at [52.215-2](#), Audit and Records—Negotiation.

(1) The Comptroller General of the United States, or an authorized representative of the Comptroller General, shall have access to and right to examine any of the Contractor's directly pertinent records involving transactions related to this contract.

(2) The Contractor shall make available at its offices at all reasonable times the records, materials, and other evidence for examination, audit, or reproduction, until 3 years after final payment under this contract or for any shorter period specified in FAR [Subpart 4.7](#), Contractor Records Retention, of the other clauses of this contract. If this contract is completely or partially terminated, the records relating to the work terminated shall be made available for 3 years after any resulting final termination settlement. Records relating to appeals under the disputes clause or to litigation or the settlement of claims arising under or relating to this contract shall be made available until such appeals, litigation, or claims are finally resolved.

(3) As used in this clause, records include books, documents, accounting procedures and practices, and other data, regardless of type and regardless of form. This does not require the Contractor to create or maintain any record that the Contractor does not maintain in the ordinary course of business or pursuant to a provision of law.

(e)(1) Reserved

(e)(1) in a subcontract for commercial items. Unless otherwise indicated below, the extent of the flow down shall be as required by the clause—

(i) [52.203-13](#), Contractor Code of Business Ethics and Conduct (APR 2010) (Pub. L. 110-252, Title VI, Chapter 1 ([41 U.S.C. 251 note](#))).

(ii) [52.219-8](#), Utilization of Small Business Concerns (May 2004) ([15 U.S.C. 637\(d\)\(2\)](#) and (3)), in all subcontracts that offer further subcontracting opportunities. If the subcontract (except subcontracts to small business concerns) exceeds \$650,000 (\$1.5m for construction of any public facility), the subcontractor must include [52.219-8](#) in lower tier subcontracts that offer subcontracting opportunities.

(iii) Reserved

(iv) [52.222-26](#), Equal Opportunity (Mar 2007) (E.O. 11246).

(v) [52.222-35](#), Equal Opportunity for Special Disabled Veterans, Veterans of the Vietnam Era, and Other Eligible Veterans (Sept 2006) ([38 U.S.C. 4212](#)).

(vi) [52.222-36](#), Affirmative Action for Workers with Disabilities (OCT 2010) ([29 U.S.C. 793](#)).

(vii) Reserved.

(viii) [52.222-41](#), Service Contract Act of 1965 (Nov 2007) ([41 U.S.C. 351](#), *et seq.*).

(ix) [52.222-50](#), Combating Trafficking in Persons (Feb 2009) ([22 U.S.C. 7104\(g\)](#)).

[ ] Alternate I (Aug 2007) of [52.222-50](#) ([22 U.S.C. 7104\(g\)](#)).

(x) [52.222-51](#), Exemption from Application of the Service Contract Act to Contracts for Maintenance, Calibration, or Repair of Certain Equipment-Requirements (Nov 2007) ([41 U.S.C. 351](#), *et seq.*).

- (xi) [52.222-53](#), Exemption from Application of the Service Contract Act to Contracts for Certain Services-Requirements (Feb 2009) ([41 U.S.C. 351](#), *et seq.*).
- (xii) [52.222-54](#), Employment Eligibility Verification (JAN 2009).
- (xiii) [52.226-6](#), Promoting Excess Food Donation to Nonprofit Organizations (Mar 2009) (Pub. L. 110-247). Flow down required in accordance with paragraph (e) of FAR clause [52.226-6](#).
- (xiv) [52.247-64](#), Preference for Privately Owned U.S.-Flag Commercial Vessels (Feb 2006) ([46 U.S.C. Appx. 1241\(b\)](#) and [10 U.S.C. 2631](#)). Flow down required in accordance with paragraph (d) of FAR clause [52.247-64](#).

(2) While not required, the contractor may include in its subcontracts for commercial items a minimal number of additional clauses necessary to satisfy its contractual obligations.

(End of clause)

**ADDENDUM TO CONTRACT CLAUSES FAR AND DOSAR CLAUSES NOT  
PRESCRIBED IN PART 12**

52.252-2      CLAUSES INCORPORATED BY REFERENCE (FEB 1998)

This contract incorporates one or more clauses by reference, with the same force and effect as if they were given in full text. Upon request, the Contracting Officer will make their full text available. Also, the full text of a clause may be accessed electronically at this/these address(es):

<http://acquisition.gov/far/index.html/> or <http://farsite.hill.af.mil/search.htm>

These addresses are subject to change. IF the FAR is not available at the locations indicated above, use of a network "search engine" (e.g., Yahoo, Infoseek, Alta Vista, etc.) is suggested to obtain the latest location of the most current FAR clauses.

The following Federal Acquisition Regulation clauses are incorporated by reference:

Clause	Title and Date
52.225-14	Inconsistency Between English Version and Translation of Contract (FEB 2000)
52.232-34	Optional Information for Electronic Funds Transfer Payment (AUG 1996)

The following FAR clause is provided in full text:

None

The following DOSAR clauses are provided in full text:

652.204-70 DEPARTMENT OF STATE PERSONAL IDENTIFICATION CARD ISSUANCE PROCEDURES (AUG 2007)

(a) The Contractor shall comply with the Department of State (DOS) Personal Identification Card Issuance Procedures for all employees performing under this contract who require frequent and continuing access to DOS facilities, or information systems. The Contractor shall insert this clause in all subcontracts when the subcontractor's employees will require frequent and continuing access to DOS facilities, or information systems.

(b) The DOS Personal Identification Card Issuance Procedures may be accessed at

<http://www.state.gov/m/ds/rls/rpt/c21664.htm> .

(End of clause)

## CONTRACTOR IDENTIFICATION (JULY 2008)

Contract performance may require contractor personnel to attend meetings with government personnel and the public, work within government offices, and/or utilize government email.

Contractor personnel must take the following actions to identify themselves as non-federal employees:

- 1) Use an email signature block that shows name, the office being supported and company affiliation (e.g. "John Smith, Office of Human Resources, ACME Corporation Support Contractor");
- 2) Clearly identify themselves and their contractor affiliation in meetings;
- 3) Identify their contractor affiliation in Departmental e-mail and phone listings whenever contractor personnel are included in those listings; and
- 4) Contractor personnel may not utilize Department of State logos or indicia on business cards.

(End of clause)

## 652.232-70 PAYMENT SCHEDULE AND INVOICE SUBMISSION (FIXED-PRICE) (AUG 1999)

(a) General. The Government shall pay the contractor as full compensation for all work required, performed, and accepted under this contract the firm fixed-price stated in this contract.

(b) Invoice Submission. The contractor shall submit invoices in an original to the office identified in Block 5 of the OF-347. To constitute a proper invoice, the invoice shall include all the items required by FAR 32.905(e).

***FMO  
American Embassy Praia  
Rua Abílio Maçedo 6  
Praia, Cape Verde***

The contractor shall show Value Added Tax (VAT) as a separate item on invoices submitted for payment.

(c) Contractor Remittance Address. The Government will make payment to the contractor's address stated on the cover page of this contract, unless a separate remittance address is shown below:

---

---

---

652.242-70 CONTRACTING OFFICER'S REPRESENTATIVE (COR) (AUG 1999)

(a) The Contracting Officer may designate in writing one or more Government employees, by name or position title, to take action for the Contracting Officer under this contract. Each designee shall be identified as a Contracting Officer's Representative (COR). Such designation(s) shall specify the scope and limitations of the authority so delegated; provided, that the designee shall not change the terms or conditions of the contract, unless the COR is a warranted Contracting Officer and this authority is delegated in the designation.

(b) Reserved

652.242-73 AUTHORIZATION AND PERFORMANCE (AUG 1999)

(a) The contractor warrants the following:

(1) That it has obtained authorization to operate and do business in the country or countries in which this contract will be performed;

(2) That it has obtained all necessary licenses and permits required to perform this contract; and,

(3) That it shall comply fully with all laws, decrees, labor standards, and regulations of said country or countries during the performance of this contract.

(b) If the party actually performing the work will be a subcontractor or joint venture partner, then such subcontractor or joint venture partner agrees to the requirements of paragraph (a) of this clause.

### SECTION 3 - SOLICITATION PROVISIONS

FAR 52.212-1, Instructions to Offerors -- Commercial Items (JUN2008), is incorporated by reference. (See SF-1449, block 27a).

ADDENDUM TO 52.212-1 None

#### ADDENDUM TO SOLICITATION PROVISIONS FAR AND DOSAR PROVISIONS NOT PRESCRIBED IN PART 12

##### 52.252-1 SOLICITATION PROVISIONS INCORPORATED BY REFERENCE (FEB 1998)

This solicitation incorporates one or more solicitation provisions by reference, with the same force and effect as if they were given in full text. Upon request, the Contracting Officer will make their full text available. Also, the full text of a clause may be accessed electronically at this/these address(es):

<http://acquisition.gov/far/index.html/> or <http://farsite.hill.af.mil/search.htm>

These addresses are subject to change. IF the FAR is not available at the locations indicated above, use of a network "search engine" (e.g., Yahoo, Infoseek, Alta Vista, etc.) is suggested to obtain the latest location of the most current FAR provisions.

The following Federal Acquisition Regulation solicitation provisions are incorporated by reference:

Clause	Title and Date
52.204-6	Data Universal Numbering System (DUNS) Number (APR 2008)
52.209-7	Information Regarding Responsibility Matters (APR 2010)
52.209-8	Updates of Information Regarding Responsibility Matters (APR 2010)
52.214-34	Submission of Offers in the English Language (APR 1991)

The following DOSAR provision is provided in full text:

##### 652.206-70 COMPETITION ADVOCATE/OMBUDSMAN (AUG 1999) (DEVIATION)

- (a) The Department of State's Competition Advocate is responsible for assisting industry in removing restrictive requirements from Department of State solicitations and removing barriers to full and open competition and use of commercial items. If such a solicitation is considered competitively restrictive or does not appear properly conducive to competition and commercial practices, potential offerors are encouraged to first contact the contracting office for the respective solicitation. If concerns remain unresolved, contact the Department of State Competition Advocate on (703) 516-1693, by fax at (703) 875-6155, or write to: U.S. Department of State, Competition Advocate, Office of the Procurement Executive (A/OPE), Suite 900, SA-27, Washington, DC 20522-2712.

(b) The Department of State's Acquisition Ombudsman has been appointed to hear concerns from potential offerors and contractors during the pre-award and post-award phases of this acquisition. The role of the ombudsman is not to diminish the authority of the contracting officer, the Technical Evaluation Panel or Source Evaluation Board, or the selection official. The purpose of the ombudsman is to facilitate the communication of concerns, issues, disagreements, and recommendations of interested parties to the appropriate Government personnel, and work to resolve them. When requested and appropriate, the ombudsman will maintain strict confidentiality as to the source of the concern. The ombudsman does not participate in the evaluation of proposals, the source selection process, or the adjudication of formal contract disputes. Interested parties are invited to contact the contracting activity ombudsman, Richard Reilly, at *tel. 2608900 and fax 2611355*. For an American Embassy or overseas post, refer to the numbers below for the Department Acquisition Ombudsman. Concerns, issues, disagreements, and recommendations which cannot be resolved at a contracting activity level may be referred to the Department of State Acquisition Ombudsman at (703) 516-1693, by fax at (703) 875-6155, or write to: Department of State, Acquisition Ombudsman, Office of the Procurement Executive (A/OPE), Suite 900, SA-27, Washington, DC 20522-2712.

Acquisition Method: The Government is conducting this acquisition using the simplified acquisition procedures in Part 13 of the Federal Acquisition Regulation (FAR). If the dollar amount exceeds the simplified acquisition threshold, then the Government will be using the test program for commercial items authorized by Subpart 13.5 of the FAR.

## **SECTION 4 - EVALUATION FACTORS**

Award will be made to the lowest priced, acceptable, responsible quoter, which can meet the equipment availability, delivery and shipping requirements herein. Quotes shall include a completed solicitation. Provide manufacturers technical specifications and information on the generator sets, transfer switches and associated components, listed in Table I.

Unit Prices for generator, transfer switch, spare parts kit and trailer shall be listed.

The Government reserves the right to reject proposals that are unreasonably low or high in price.

The lowest price will be determined by multiplying the offered prices times the estimated quantities in Prices - Continuation of SF-1449, block 23 or applicable page of this Solicitation, and arriving at a grand total, including all line items. Acceptability will be determined by assessing the offeror's compliance with the terms of the RFP. Responsibility will be determined by analyzing whether the apparent successful offeror complies with the requirements of FAR 9.1, including:

- \* equipment availability and delivery schedule;
- \* adequate financial resources or the ability to obtain them;
- \* ability to comply with the required performance period, taking into consideration all existing commercial and governmental business commitments;
- \* satisfactory record of integrity and business ethics;
- \* necessary organization, experience, and skills or the ability to obtain them;
- \* necessary equipment and facilities or the ability to obtain them; and
- \* be otherwise qualified and eligible to receive an award under applicable laws and regulations.

**ADDENDUM TO EVALUATION FACTORS  
FAR AND DOSAR PROVISION(S) NOT PRESCRIBED IN PART 12**

The following FAR provision is provided in full text:

FAR 52.225-17 EVALUATION OF FOREIGN CURRENCY OFFERS (FEB 2000):

If the Government receives offers in more than one currency, the Government will evaluate offers by converting the foreign currency to United States currency using the exchange rate used by the Embassy in effect as follows:

- (a) For acquisitions conducted using sealed bidding procedures, on the date of bid opening.
- (b) For acquisitions conducted using negotiation procedures—
  - (1) On the date specified for receipt of offers, if award is based on initial offers; otherwise
  - (2) On the date specified for receipt of proposal revisions.

## SECTION 5 - OFFEROR REPRESENTATIONS AND CERTIFICATIONS

### 52.212-3 OFFEROR REPRESENTATIONS AND CERTIFICATIONS – COMMERCIAL ITEMS (OCT 2010)

An offeror shall complete only paragraph (b) of this provision if the offeror has completed the annual representations and certifications electronically at <http://orca.bpn.gov>. If an offeror has not completed the annual representations and certifications electronically at the ORCA website, the offeror shall complete only paragraphs (c) through (m) of this provision.

(a) Definitions. As used in this provision—

“Emerging small business” Reserved

“Forced or indentured child labor” means all work or service—

(1) Exacted from any person under the age of 18 under the menace of any penalty for its nonperformance and for which the worker does not offer himself voluntarily; or

(2) Performed by any person under the age of 18 pursuant to a contract the enforcement of which can be accomplished by process or penalties.

“Inverted domestic corporation,” as used in this section, means a foreign incorporated entity which is treated as an inverted domestic corporation under 6 U.S.C. 395(b), i.e., a corporation that used to be incorporated in the United States, or used to be a partnership in the United States, but now is incorporated in a foreign country, or is a subsidiary whose parent corporation is incorporated in a foreign country, that meets the criteria specified in 6 U.S.C. 395(b), applied in accordance with the rules and definitions of 6 U.S.C. 395(c).”

“Manufactured end product” means any end product in Federal Supply Classes (FSC) 1000-9999, except—

- (1) FSC 5510, Lumber and Related Basic Wood Materials;
- (2) Federal Supply Group (FSG) 87, Agricultural Supplies;
- (3) FSG 88, Live Animals;
- (4) FSG 89, Food and Related Consumables;
- (5) FSC 9410, Crude Grades of Plant Materials;
- (6) FSC 9430, Miscellaneous Crude Animal Products, Inedible;
- (7) FSC 9440, Miscellaneous Crude Agricultural and Forestry Products;
- (8) FSC 9610, Ores;
- (9) FSC 9620, Minerals, Natural and Synthetic; and
- (10) FSC 9630, Additive Metal Materials.

“Place of manufacture” means the place where an end product is assembled out of components, or otherwise made or processed from raw materials into the finished product that is to be provided to the Government. If a product is disassembled and reassembled, the place of reassembly is not the place of manufacture.

“Restricted business operations” means business operations in Sudan that include power production activities, mineral extraction activities, oil-related activities, or the production of military equipment, as those terms are defined in the Sudan Accountability and Divestment Act of 2007 (Pub. L. 110-174). Restricted business operations do not include business operations that the person (as that term is defined in Section 2 of the Sudan Accountability and Divestment Act of 2007) conducting the business can demonstrate—

- (1) Are conducted under contract directly and exclusively with the regional government of southern Sudan;
- (2) Are conducted pursuant to specific authorization from the Office of Foreign Assets Control in the Department of the Treasury, or are expressly exempted under Federal law from the requirement to be conducted under such authorization;
- (3) Consist of providing goods or services to marginalized populations of Sudan;
- (4) Consist of providing goods or services to an internationally recognized peacekeeping force or humanitarian organization;
- (5) Consist of providing goods or services that are used only to promote health or education; or
- (6) Have been voluntarily suspended.

“Service-disabled veteran-owned small business concern”— Reserved

“Small business concern” – Reserved

“Veteran-owned small business concern” – Reserved

“Women-owned business concern” - Reserved

“Women-owned small business concern” – Reserved

- (b) (1) Annual Representations and Certifications. Any changes provided by the offeror in paragraph (b)(2) of this provision do not automatically change the representations and certifications posted on the Online Representations and Certifications Application (ORCA) website.

- (2) The offeror has completed the annual representations and certifications electronically via the ORCA website at <http://orca.bpn.gov>. After reviewing the ORCA database information, the offeror verifies by submission of this offer that the representations and certifications currently posted electronically at FAR 52.212-3, Offeror Representations and Certifications—Commercial Items, have been entered or updated in the last 12 months, are current, accurate, complete, and applicable to this solicitation (including the business size standard applicable to the NAICS code referenced for this solicitation), as of the date of this offer and are incorporated in this offer by reference (see FAR 4.1201), except for paragraphs\_\_\_\_\_.

***[Offeror to identify the applicable paragraphs at (c) through (m) of this provision that the offeror has completed for the purposes of this solicitation only, if any. These amended representation(s) and/or certification(s) are also incorporated in this offer and are current, accurate, and complete as of the date of this offer. Any changes provided by the offeror are applicable to this solicitation only, and do not result in an update to the representations and certifications posted on ORCA.]***

(c) – (d) Reserved

- (e) Certification Regarding Payments to Influence Federal Transactions ([31 U.S.C. 1352](#)). (Applies only if the contract is expected to exceed \$150,000.) By submission of its offer, the offeror certifies to the best of its knowledge and belief that no Federal appropriated funds have been paid or will be paid to any person for influencing or attempting to influence an officer or employee of any agency, a Member of Congress, an officer or employee of Congress or an employee of a Member of Congress on his or her behalf in connection with the award of any resultant contract. If any registrants under the Lobbying Disclosure Act of 1995 have made a lobbying contact on behalf of the offeror with respect to this contract, the offeror shall complete and submit, with its offer, OMB Standard Form LLL, Disclosure of Lobbying Activities, to provide the name of the registrants. The offeror need not report regularly employed officers or employees of the offeror to whom payments of reasonable compensation were made.

(f) – (g) Reserved

(h) Reserved

- (i) Certification Regarding Knowledge of Child Labor for Listed End Products (Executive Order 13126).

(1) Listed end products.

(2) Certification.

(i) The offeror will not supply any end product listed in paragraph (i)(1) of this provision that was mined, produced, or manufactured in the corresponding country as listed for that product.

(ii) The offeror may supply an end product listed in paragraph (i)(1) of this provision that was mined, produced, or manufactured in the corresponding country as listed

for that product. The offeror certifies that it has made a good faith effort to determine whether forced or indentured child labor was used to mine, produce, or manufacture any such end product furnished under this contract. On the basis of those efforts, the offeror certifies that it is not aware of any such use of child labor.

- (j) Place of manufacture. (Does not apply unless the solicitation is predominantly for the acquisition of manufactured end products.) For statistical purposes only, the offeror shall indicate whether the place of manufacture of the end products it expects to provide in response to this solicitation is predominantly—

(1)  In the United States (Check this box if the total anticipated price of offered end products manufactured in the United States exceeds the total anticipated price of offered end products manufactured outside the United States); or

(2)  Outside the United States

- (k) Reserved

- (l) Taxpayer Identification Number (TIN) ([26 U.S.C. 6109](#) [31 U.S.C. 7701](#)). (Not applicable if the offeror is required to provide this information to a central contractor registration database to be eligible for award.)

(1) All offerors must submit the information required in paragraphs (l)(3) through (l)(5) of this provision to comply with debt collection requirements of [31 U.S.C. 7701\(c\)](#) and [3325\(d\)](#), reporting requirements of [26 U.S.C. 6041](#), [6041A](#), and [6050M](#), and implementing regulations issued by the Internal Revenue Service (IRS).

(2) The TIN may be used by the Government to collect and report on any delinquent amounts arising out of the offeror's relationship with the Government ([31 U.S.C. 7701\(C\)\(3\)](#)). If the resulting contract is subject to the payment reporting requirements described in FAR [4.904](#), the TIN provided hereunder may be matched with IRS records to verify the accuracy of the offeror's TIN.

- (3) Taxpayer Identification Number (TIN).

TIN: \_\_\_\_\_.

TIN has been applied for.

TIN is not required because:

Offeror is a nonresident alien, foreign corporation, or foreign partnership that does not have income effectively connected with the conduct of a trade or business in the United States and does not have an office or place of business or a fiscal paying agent in the United States;

Offeror is an agency or instrumentality of a foreign government;

Offeror is an agency or instrumentality of the Federal Government.

- (4) Type of organization.

- Sole proprietorship;
- Partnership;
- Corporate entity (not tax-exempt);
- Corporate entity (tax-exempt);
- Government entity (Federal, State, or local);
- Foreign government;
- International organization per 26 CFR 1.6049-4;
- Other \_\_\_\_\_.

(5) Common parent.

- Offeror is not owned or controlled by a common parent;
- Name and TIN of common parent:

Name \_\_\_\_\_.  
TIN \_\_\_\_\_.

(m) Restricted business operations in Sudan. By submission of its offer, the offeror certifies that it does not conduct any restricted business operations in Sudan.

(n) Prohibition on Contracting with Inverted Domestic Corporations. (1)Relation to Internal Revenue Code. A foreign entity that is treated as an inverted domestic corporation for purposes of the Internal Revenue Code at 26 USC 7874 (or would be except that the inversion transactions were completed on or before March 4, 2003), is also an inverted domestic corporation for purposes of 6 USC 395 and for this solicitation provision (see FAR 9.108).

(2) Representation. By submission of its offer, the offeror represents that it is not an offer, the offeror represents that is not an inverted domestic corporation and is not a subsidiary of one.

(End of Clause)

**ADDENDUM TO OFFEROR REPRESENTATIONS AND CERTIFICATIONS FAR AND  
DOSAR PROVISION(S) NOT PRESCRIBED IN PART 12**

The following DOSAR provision is provided in full text:

652.225-70 ARAB LEAGUE BOYCOTT OF ISRAEL (AUG 1999)

(a) Definitions. As used in this provision:

Foreign person means any person other than a United States person as defined below.

United States person means any United States resident or national (other than an individual resident outside the United States and employed by other than a United States person), any domestic concern (including any permanent domestic establishment of any foreign concern), and any foreign subsidiary or affiliate (including any permanent foreign establishment) of any domestic concern which is controlled in fact by such domestic concern, as provided under the Export Administration Act of 1979, as amended.

(b) Certification. By submitting this offer, the offeror certifies that it is not:

- (1) Taking or knowingly agreeing to take any action, with respect to the boycott of Israel by Arab League countries, which Section 8(a) of the Export Administration Act of 1979, as amended (50 U.S.C. 2407(a)) prohibits a United States person from taking; or,
- (2) Discriminating in the award of subcontracts on the basis of religion.

## **SECTION 6 - PROPOSAL PREPARATION INSTRUCTIONS**

### 6.1 General

### 6.2 Specific Requirements:

6.2.1 This solicitation incorporates the FAR provision 52.212-1, "Instructions to Offerors - Commercial Items.

The following Federal Acquisition Regulation clauses are incorporated in full text:

#### 52.215-5 FACSIMILE PROPOSALS (OCT 1997)

- (a) Definition. "Facsimile proposal," as used in this provision, means a proposal, revision or modification of a proposal, or withdrawal of a proposal that is transmitted to and received by the Government via facsimile machine.
- (b) Offerors may submit facsimile proposals as response to this solicitation. Facsimile proposals are subject to the same rules as paper proposals.
- (c) The telephone number of receiving facsimile equipment is: (809) 685-9019.
- (d) If any portion of a facsimile proposal received by the Contracting Officer is unreadable to the degree that conformance to the essential requirements of the solicitation cannot be ascertained from the document-
  - (1) The Contracting Officer immediately shall notify the offeror and permit the offeror to resubmit the proposal;
  - (2) The method and time for resubmission shall be prescribed by the Contracting Office after consultation with the offeror; and
  - (3) The resubmission shall be considered as if it were received at the date and time of the original unreadable submission for the purpose of determining timeliness, provided the offeror complies with the time and format requirements for resubmission prescribed by the Contracting Officer.
- (e) The Government reserves the right to make award solely on the facsimile proposal. However, if requested to so by the Contracting Officer, the apparently successful offeror promptly shall submit the complete original signed proposal.