

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE D		PAGE OF PAGES 1 2	
2. AMENDMENT/MODIFICATION NO. A-001		3. EFFECTIVE DATE 5/10/2016		4. REQUISITION/PURCHASE REQ. NO. PR5228691		5. PROJECT NO. (If applicable)
6. ISSUED BY GSO Procurement U.S. Embassy in Moscow Bolshoy Deviatinsky Pereulok No. 8 Moscow 121099, Russian Federation			CODE 19RS50	7. ADMINISTERED BY (If other than Item 6) CODE		
8. NAME AND ADDRESS OF CONTRACTOR (NO., street, city, county, State, and ZIP Code)				9a. AMENDMENT OF SOLICITATION NO. SRS500-16-Q-PR5228691		
				9b. DATED (SEE ITEM 11) 04/25/2016		
				10a. MODIFICATION OF CONTRACT/ORDER NO.		
				10b. DATED (SEE ITEM 13)		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS						
<p>[X] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [] is extended, [X] is not extended</p> <p>Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning 1 copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers.</p> <p>FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.</p>						
12. ACCOUNTING AND APPROPRIATION DATA (If required)						
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.						
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.						
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b)						
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
D. OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor is [X] not, is [] required to sign this document and return 1 copy to the issuing office.						
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)						
This amendment is issued to answer questions that have been asked by potential offerors. See page 2 "Questions and Answers".						
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.						
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME OF CONTRACTING OFFICER Myron V. Hirniak		
15B. NAME OF CONTRACTOR/OFFEROR BY _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY Myron V. Hirniak (Signature of Contracting Officer)		16C. DATE SIGNED 5/10/2016

Questions and Answers

Q1: Please clarify if the overall thickness of the wall to be constructed must be exactly 150 millimeters or if we can build a thicker wall if our proposed door mechanism makes the overall thickness a little greater.

A1: Amend Section B.3.1 *Work Description*, Paragraph *Overall Wall Dimensions* to now read: “Overall wall dimensions: wall width 3.55 meters, wall height 3 meters, approximate wall thickness 150 millimeters (the actual wall thickness is to be determined by the Contractor depending on the type of door mechanism proposed to be used for this project). Please reference the revised Attachment 2 “Drawings: Door Plan” included in Amendment A-002.

Q2: Can we propose to also install a door closer for the new door?

A2: A door closer is not needed for this project.

Q3: We think that stainless steel protection for the door opening will be a much better solution than the aluminum frame currently specified in the Scope of Work and the original door plan drawings.

A3: Agree. Amend Section B.3.1 *Work Description*, Paragraph 7 to now read: “The door shall be painted grey color RAL 7012. The door opening must be framed on all sides with stainless steel corners as shown in the revised door plan drawings.” Please reference the revised Attachment 2 “Drawings: Door Plan” included in Amendment A-002.

Q4: Please specify the width of the threshold for the door opening.

A4: The stainless steel threshold in the door opening must be equal to the thickness of the wall to be constructed.

Q5: Please specify if the Embassy is going to provide only the lock cylinder or the entire door lock for the new door.

A5: The Embassy is going to provide the entire door lock.

Q6: If during the course of work for the project we discover that we need to replace a few floor tiles and put the new baseboard in, will the Embassy be able to provide these materials?

A6: Yes.

END OF QUESTIONS AND ANSWERS SECTION