

P.O.Box 9123

Dar es Salaam

Tanzania

February 20, 2013

Dear Sir/Madam

REQUEST FOR QUOTATION #PR2346358

The Embassy of the United States of America is looking for potential vendors who are interested in bidding on the following project :(Scope of Work)

- 1).Locate, design build, complete with sketches a new septic tank with leach field to be built to replace existing one. Size is approximate 8,000 liter septic tank capacity with appropriate inlets and discharge pipes all provided by the contractor. Leach field will be at least 90 CM depth and a length of not less than 15 meters and will use 4 inch perforated plastic sewage type discharge pipe with a design slope of not less than 3 degrees per 20 meters and it will employ a slope away from the septic tank to allow for adequate drainage. Under the perforated pipe will be a bed of soft water porous sand of not less than 150 MM depth and below the porous sand will be a bed of crushed rock not less than 300 MM depth to allow for drainage easy. The top of the leach field will be covered back by the same top soil removed and it will have a bed of soft sand or dirt above the discharge pipe to protect it. The bottom of the new septic tank will be not less than 100 MM, the side wall of the new tank will be not less than 100 MM thick, the top of the septic tank will be not less than 100 MM Thick with a inspection door and a vent pipe protruding up at least 75 CM and will employ a 180 degree bend to allow for venting without allowing rain to enter. The top inspection door will be constructed of steel or iron plate of at least 6 MM thickness.
- 2). Contractor is responsible for design build, complete with sketches and design at time of bid proposal submittal.
- 3). Contractor is responsible for all clean up of all areas to include complete sand filling of the existing septic tank,
- 4). Contractor is responsible for all procurement actions and is subject to daily inspections.
- 5). Contractor is to protect all sidewalks

If you would like to submit a quotation fills in the appropriate sections of form SF1442 or provides a proforma invoice.

Your quotations must be received in sealed envelope marked "Quotation Enclosed" on or before March 05th, 2013 at 1600. Address the envelope as follow

Contracting Officer

Attn: Facility Manager

US Embassy

P.O.Box 9123 Dar es salaam

686 Old Bagamoyo Road Msasani

Dar es Salaam

Any question regarding this request for quotation must be directed to Procurement Section on Telephone # 2294138, 2294263, 2294121 during office hours.

Sincerely

Buck R. Tilley

Contracting Officer