

Purchase of LED Pole Lights

Procurement Reference Number: **PR2538950**

Requirement

The Mission invites responsible vendors to provide quotations for the purchase of LED Pole Lights as is mentioned here below;

<u>Item Description</u>	<u>Quantity</u>
1. LED Area Light; Model #: MLAR140LED50/5W or Equivalent	25
2. LED Area Light; Model #: MLAR100LED50/5W or Equivalent	15

General Specifications:

- Color Temperature: 5000K
- CRI > 66
- Input Voltage: Universal 100V to 277V, 50/60 Hz driver
- 6" extruded aluminum arm included
- Power Factor – Over 90%
- Humidity: 20%-85% RH, non condensing
- EPA: 1.10
- Full cutoff classification both type V square and wide distributions
- Constructed without any hazardous materials
- Compatible with mechanical relay type Photocell and occupancy sensor
- Color Consistency: Proprietary Binning for uniform color
- LM-79/80 reports available
- Lamp Life: 50,000 Hours
- Dimensions – 16.5" x 16.5" x 7.5 (L" X W" X H")
- Environment: Outdoor
- Five Year Limited Warranty

Please indicate your Source (origin) of items; i.e. Country of Origin and any other specifications you may deem fit to enable decision making.

Issue of Notice and Due by Dates

Issued Date: Friday, May 24, 2013

Closing Date: Friday, June 07, 2013 at 09:00am

Please submit your quotes to MagalaDN@state.gov and copy KiyinqiDX@state.gov and RaoS@state.gov

Delivery Point

General Services Offices

American Embassy Kampala

Plot 63/67, Spring Road, Bugolobi

Kampala, Uganda

Terms and Conditions:

This RFQ incorporates by reference FAR 52.212-5 AND 52.252-2, with the same force and effect as if they were given in full text. The full text of this clause may be accessed electronically at: <https://www.acquisition.gov/far/index.html>

Contacts

For further details please contact: MagalaDN@state.gov