

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

1. CONTRACT ID CODE PAGE OF PAGES
1 1

2. AMENDMENT/MODIFICATION NO. 3. EFFECTIVE DATE 4. REQUISITION/PURCHASE REQ. NO. 5. PROJECT NO. (If applicable)
A002 05-18-2016 PR5227790

6. ISSUED BY CODE 7. ADMINISTERED BY (If other than Item 6) CODE
US Embassy
4 Igor Sikorsky St.
04112, Kyiv, Ukraine

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) (X) 9A. AMENDMENT OF SOLICITATION NO.
SUP300-16-Q-0009
9B. DATED (SEE ITEM 11)
04-13-2016
10A. MODIFICATION OF CONTRACT/ORDER NO.
10B. DATED (SEE ITEM 13)
CODE FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
(a) By completing items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

CHECK ONE A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

The purpose of this amendment is to modify the scope work in the paragraphs identified below and to extend offers due date- please see attached pages.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print) 16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)
Trisha Presto, Contracting Officer
15B. CONTRACTOR/OFFEROR 15C. DATE SIGNED 16B. UNITED STATES OF AMERICA 16C. DATE SIGNED
(Signature of person authorized to sign) (Signature of Contracting Officer) 5/18/16

**1) Section I - the Schedule, Schedule of Supplies/Services/Prices/ (Block 20/Block 23),
Description/Specifications/Work Statement, paragraph 1.0 Project Description is modified as follows:**

The US Embassy in Kyiv has a requirement to perform installation of a new 88 kVA standby rated diesel engine generator and associated automatic transfer switch (ATS). The new generator is to provide emergency backup power for the Deputy Chief of Mission Residence (DCMR) building located at 54, Sichovykh Striltsiv (former Artema) Street in Kyiv.

There is currently no back up power for this compound, but it is desired that all DCMR building loads be placed under automatic generator power when utility power is lost. The new generator shall be a diesel generator set with a standby rating of 88 kVA or higher, weatherproof and sound limiting housing enclosure, 380Y/220 nominal voltage, 3 phase, 50 hertz, complete with automatic transfer switch, and is to be interconnected to the DCMR building's electrical distribution system.

Included in this effort is the Contractor Furnished and Contractor Installed (CFCI) two new 1000 liters or double-walled main fuel tanks as well as power and control wiring, properly sized load wires with conduits or cable trays, and other miscellaneous works identified below. Further, this effort includes the restoration of all affected parts of the facility to acceptable condition.

**2) Section I - the Schedule, Schedule of Supplies/Services/Prices/ (Block 20/Block 23),
Description/Specifications/Work Statement, paragraph 2.0 Scope is modified as follows:**

The contractor shall provide equipment, labor, materials, and installation drawing plans necessary to install a complete new operational generator power system including ATS. This includes the installation of generator, automatic transfer switch, two main fuel tanks, feeder circuits, and modifications to the existing building electrical distribution system, connection to the existing electrical distribution system, control circuit, equipment foundation, and fuel lines. The contractor must also provide testing and coordination for a safe and fully operational generator power system. The generator will be furnished by the US Embassy, Kyiv, Ukraine.

**3) Section I - the Schedule, Schedule of Supplies/Services/Prices/ (Block 20/Block 23),
Description/Specifications/Work Statement, paragraph 3.0 Project Requirements, article 3.2 is modified as follows:**

Contractor Furnished-Contractor Installed Material: The contractor shall furnish automatic transfer switch, two main fuel tanks 1000 liters each and all other equipment and materials required under this SoW.

**4) Section I - the Schedule, Schedule of Supplies/Services/Prices/ (Block 20/Block 23),
Description/Specifications/Work Statement, paragraph 4.0 Technical Requirements, article 4.1 is modified as follows:**

Diesel Generator Set: Contractor shall install the Government furnished standby duty diesel generator set with associated controls to provide a fully automatic system to support the DCMR Building's total

connected load. The new generator set shall be installed on the north side of the back yard (behind the DCMR building). Contractor shall provide the required clearance area for generator service (1,200mm around the genset), coordinate it with local codes and the Embassy Facility Manager approval. The contractor shall be thoroughly familiar with the generator set manufacturer's installation requirements.

5) Section I - the Schedule, Schedule of Supplies/Services/Prices/ (Block 20/Block 23), Description/Specifications/Work Statement, paragraph 4.0 Technical Requirements, article 4.6 is modified as follows:

Generator Fuel Supply: Contractor shall provide and install the necessary fuel supply and return lines in accordance with the requirement of the engine manufacturer. All fuel lines shall be suitable for diesel fuel and sized for the engine capacity or as recommended by the engine manufacturer. The generator shall have a day fuel tank within the generator enclosure as well as two main fuel tanks 1000 liters each, and all other required equipment and materials. All fuel needed for testing will be provided by the US Embassy.

6) Section I - the Schedule, Schedule of Supplies/Services/Prices/ (Block 20/Block 23), Description/Specifications/Work Statement, paragraph 4.0 Technical Requirements, article 4.7 is modified as follows:

Equipment Concrete Foundation and Slab On Grade: Provide generator set concrete and steel reinforced foundation in accordance with the recommendation of the generator set manufacturer. Provide steel reinforced concrete foundation and slab on grade to accommodate the total weight of the equipment and weatherproof enclosure. The generator and slab shall be placed to allow a minimum 3 foot walk space around and to allow manufacturer recommended clearances on all sides of the generator.

7) Section I - the Schedule, Schedule of Supplies/Services/Prices/ (Block 20/Block 23), Description/Specifications/Work Statement, paragraph 14.0 Preparation of Installation Drawings: Submission Requirements, article 14.1 is modified as follows:

Submittal: Prior to equipment procurement and installation, the contractor shall submit to COR, two (2) sets of installation drawings, specifications of materials/equipment to be procured, including catalog data/cut sheets of equipment and materials, and his installation schedules for COR review and approval. The specifications or catalog data/cut sheets of equipment must include the ATS, two main fuel tanks, batteries, battery charger, conduits, electrical cables, etc.

8) Section I - the Schedule, Schedule of Supplies/Services/Prices/ (Block 20/Block 23), Description/Specifications/Work Statement, paragraph 15.0 Project Schedule is modified as follows:

The installation work is desired to commence no later than **July 18, 2016**. An alternate commencement date shall be coordinated with the CO as needed by the US Government. The on-site electrical installation work shall be completed within 30 calendar days of start. The civil work may be done in advance of the electrical at any time after the approval of the installation drawings. The contractor shall not deliver any equipment or materials to the site prior to the agreed start date.

9) Section I - the Schedule, Schedule of Supplies/Services/Prices/ (Block 20/Block 23), Description/Specifications/Work Statement, paragraph 21.0 Item Pricing is modified as follows:

The offeror/quoter should provide a fixed cost price to meet this scope of work. The prices below shall include all direct and indirect costs, insurance (see FAR 52.228-4 and 52.228-5), overhead, and profit.

Value Added Tax (VAT) is not included in the CLIN rates. Instead, it will be priced as a separate Line Item in the contract and on Invoices. Local law dictates the portion of the contract price that is subject to VAT; this percentage is multiplied only against that portion. It is reflected for each performance period. The portions of the solicitation subject to VAT are:

#	Name	Name of Manufacturer and Model	Quantity, pcs	Price per unit, VAT excluded	Amount, VAT excluded
1	Automatic Transfer Switch (ATS)		1		
2	Fuel tank 1000 liters		2		
3	Other materials and equipment according to SoW	x	x	x	
4	All installation works, civil works, training for personnel, landscaping and paving works needed to accomplish the project successfully according to SoW	x	x	x	
TOTAL, VAT excluded:					
TOTAL, VAT included:					

The Government will not consider any claim for any additional compensation unless it has been authorized by the Government in writing in advance. The Government shall not be responsible for any work performed that is not specifically provided for under this contract or authorized by the Government in writing in advance.

Payment will be performed in the local currency. In case the price is submitted in another than local currency, the payment will be provided in the local currency anyway, based on the official NBU currency exchange rate on the date of final invoicing.

According to U.S. Federal Acquisition Regulations (FAR), advance payments are prohibited. Pursuant to the Prompt Payment Act of the FAR, the U.S. Government must make the payment within 30 calendar days after receipt of the goods and services and the valid original invoice(s). The offeror/quoter should confirm in the offer that these payment terms are acceptable.

10) The additional site visit will be held on May 24, 2016 at 11:00 (local time) at 54 Sichovyh Striltsiv St., Kyiv. Prospective quoters should contact Alla Biguniak at KyivGSO@state.gov or +38-044-521-5000 for additional information or to arrange entry to the building.

11) The offer due date is hereby extended from 17:00 May 20, 2016 to 17:00 June 24, 2016 for an extension of 35 days.