



*American Embassy, New Delhi, India
Shanti Path, Chanakyapuri,
New Delhi-110021
Phone No. 91-11-24198728
Fax No. 91-11-24198278*

Solicitation No. S-IN650-16-Q-0131

Dated: August 23, 2016

→ Name & address of Offeror

Issued by: M/GSO/Contracting

You are invited to quote your lowest prices for the listed services at the space provided and send it through email to newdelhibids@state.gov no later than 1000 hours on **September 07, 2016**. The Offeror must write their name, address and contact phone number on each page. The Contracting Officer shall provide additional information and/or clarifications concerning this solicitation.

Services - Description

Supply of as per Annexure –A

Installation of AHU

Rs. _____

VAT/CST

Rs. _____

Total

Rs. _____

1. Walk-thru will be held on August 29, 2016 at American Center, 24 Kasturba Gandhi Marg, Connaught Place at 1155 Hrs. (morning). To attend walkthrough please provide following information as per I.D. card which attendee will carry all the time.

| S.NO. | Name | PHONE NUMBER |
|-------|------|--------------|
| | | |
| | | |
| | | |

2. In order to enable the Government to claim VAT refunds, the offerors shall indicate VAT separately. If VAT is indicated separately, the contractor shall furnish tax invoices in accordance with Delhi VAT regulations.
3. Delivery: Delivery within 60 days of the receipt of the confirm order.
4. This purchase shall be bound by the FAR & DOSAR clauses enclosed as Annexure-B. Upon request, the Contracting Officer will make their full text available. Also, the full text of clause may be accessed electronically at the address: <http://www.acqnet.gov/far>. DOSAR Clauses may be accessed at <http://www.statebuy.state.gov/dosar/dosartoc.htm>
5. Award will be made to the **“Technically Acceptable Lowest Price”** offer. The U. S. Government reserves the right to reject any offer which is very low or high.

- 6. In case of late receipt of offer, it shall be sole discretion of the Contracting Officer (CO), to accept or reject the offer.
- 7. The offer should be submitted **ONLY** at the e-mail ID newdelhibids@state.gov with the subject line as "**Solicitation No. S-IN650-16-Q-0131**".
- 8. **The quotation should be submitted by 1000 hours on September 07, 2016.**

Name of the Offeror _____

Sincerely,

Signature _____ Dated _____

Telephone # _____ Fax# _____

Email ID: _____



Vanja Vukota
Contracting Officer

SUPPLY AND ASSEMBLING OF ONE AHU FOR AMERICAN CENTER

Name of Work: Supply and assembling of one 24 ton, 13000 cfm capacity Fresh air handling units. The air handling unit shall be for roof top at American Center New Delhi.

Brief Description:

The scope of work is as follows:

- (a) Supply of one partially treated AHU 24 ton, with definite 13000 cfm required capacity outdoor type, double skin pre plasticized air handling units floor mounted type fabricated out of extruded aluminum section. The AHU consisting of fresh air inlet, supply air inlet, cooling/heating coil made of aluminum finned copper tube with 6 row deep coil sections, fan sections imported centrifugal forward curved fan, drive assembly set, motor 'v' belts, pre cassette type filters 50mm thick, S.S drain pan and 35 mm drain pipe, duly insulated with 13mm closed cell
- (b) Test and assembling the air-handling units with specified parameters after the installation contractor completes the installation work.
- (c) The contractor should provide three sets of drawings with complete data's and details. The contractor shall proceed to manufacture the product after receiving the approved drawing.
- (d) The installation work will be carried out by Embassy through a separate contract.
- (e) Provide one set of as built drawing and Operation, repair and Maintenance manual at the time delivery of AHU

Contractors are advised to go through the attached scope of work & specifications.

Please quote your lump sum price for the entire work including all overheads and local taxes etc.

Note:

This will be a lump sum contract and nothing extra will be entertained on any account.

First phase comprises of supply of air handling units. The second phase comprises testing and commissioning of the equipment. The work to be carried out by professional workers and certified fitter and sheet metal worker in good workmanship and neat manner as per the 1996 SMACNA "HVAC Duct Construction Standards.

The supplier/ manufacturer will arrange for a dedicated full time engineer/supervisor at the time of commissioning of the equipment.

Enclosure:

- 1 Scope of work**
- 2 Specifications**

Specification of AHU

PART 1 - PRODUCTS

1.1 MANUFACTURERS

- A. Available Manufacturers: **Subject to compliance with requirements, manufacturers offering products that may be incorporated into the Work include, but are not limited to, the following:**
- B. Manufacturers: Subject to compliance with requirements, provide products by **one of the following or equivalent to meet the specification:**

1.2 MANUFACTURED UNITS

- A. General Description: Factory assembled, consisting of fans, motor and drive assembly, coils, damper, plenums, filters, drip pans, and mixing dampers.
- B. Motor and Electrical Components:
- C. Except as other wise indicated, provide manufacturer's standard products of categories and types required for each application.
- D. Provide Engraved plastic Laminate Labels, Signs and Instruction plate minimum size 130sq.cm. The engrave legend in white letters on black face and punch for mechanical fasteners.

1.3 CABINET

- A. Materials: Formed and reinforced galvanized steel panels, fabricated to allow removal for access to internal parts and components, with joints between sections sealed. Units is located indoor shall be treated with a corrosion protective coating.
 - 1. Outside Casing: Steel, 0.0598 inch (1.5 mm).
 - 2. Outside Casing: Galvanized steel, 0.0516 inch (1.0 mm).
 - 3. Inside Casing: Galvanized steel, 0.0276 inch (0.7 mm).
 - 4. Drain Plate: Stainless steel, (16 gauge)
 - 5. Floor Plate: GI, (3.0 mm).
- B. Insulation: Coated, glass-fiber insulation, complying with NFPA 90A, "Installation of Air Conditioning and Ventilating Systems," for insulation A. Hot Surfaces: Normal operating temperatures of 100 deg F (38 deg C) or higher.
- B. Dual-Temperature Surfaces: Normal operating temperatures that vary from hot to cold.
- C. Cold Surfaces: Normal operating temperatures less than 75 deg F (24 deg C).
- D. Thermal resistivity is designated by an r-value that represents the reciprocal of thermal conductivity (k-value). Thermal conductivity is the rate of heat flow through a homogenous material exactly 1 inch (25.4 mm) thick. Thermal resistivity (r-value) is expressed by the temperature difference in degrees Fahrenheit (Kelvins) between the two exposed faces required to cause 1 BTU per hour (1 Watt) to flow through 1 square foot (1 square meter) at mean temperatures indicated.
- E. Thermal Conductivity (k-value): Measure of heat flow through a material at a given temperature difference; conductivity is expressed in units of Btu x inch/h x sq. ft. x deg F (W x m/sq. m x K).
- F. Density: Is expressed in pcf (kg/cu. m).
- G. Material certificates, signed by the manufacturer, certifying that materials comply with specified requirements where laboratory test reports cannot be obtained.

1.4 QUALITY ASSURANCE

- A. Fire Performance Characteristics: Conform to the following characteristics for insulation including facings, cements, and adhesives, when tested according to ASTM E 84, by UL or other testing or inspecting organization acceptable to the authority having jurisdiction. Label insulation with appropriate markings of testing laboratory.
 - 1. Interior Insulation: Flame spread rating of 25 or less and a smoke developed rating of 50 or less.
 - 2. Exterior Insulation: Flame spread rating of 75 or less and a smoke developed rating of 150 or less.

- B. Access Panels and Doors: Same materials and finishes as cabinet and complete with hinges, latches, handles, and gaskets.
 - 1. Fan section shall have inspection and access panels and doors sized and located to allow periodic maintenance and inspections.
- C. Drain Pans: Formed sections of galvanized steel sheet. Fabricate pans in sizes and shapes to collect condensate from cooling coils (including coil piping connections and return bends) and humidifiers when units are operating at maximum-catalogued face velocity across cooling coil.
 - 1. Double-Wall Construction: Fill space between walls with foam insulation and seal moisture tight.
 - 2. Drain Connections: Both ends of pan.
 - 3. Pan-Top Surface Coating: Elastomeric compound.
 - 4. Units with stacked coils shall have an intermediate drain pan or drain trough to collect condensate from top coil.

1.5 FAN SECTION

- A. Fan-Section Construction: Belt-driven centrifugal fans, consisting of housing, wheel, fan shaft, bearings, motor and disconnect switch, drive assembly, and support structure, equipped with formed-steel channel base for integral mounting of fan, motor, and casing panels. Mount fan scroll, wheel, shaft, bearings, and motor on structural-steel frame, with frame mounted on base with vibration isolation. At the option of the contractor the motors may be mounted outside the unit.
- B. Housings: Fabricate from formed- and reinforced-steel panels to form curved scroll housings with shaped cutoff, spun-metal inlet bell, and access doors or panels to allow entry to internal parts and components.
- C. Fan Assemblies: Statically and dynamically balanced and designed for continuous operation at maximum rated fan speed and motor power. Fan wheel shall be double-width, double-inlet type with forward-curved blades.
 - 1. Forward Curved: Black steel with enamel or galvanized finish, and having an inlet flange, back plate, shallow blades with inlet and tip curved forward in direction of airflow, and steel hub.
 - 2. Shafts: Hot-rolled steel; turned, ground, and polished, and having keyway to secure to fan wheel hub.
 - 3. Shaft Bearings: Pre-lubricated and sealed, self-aligning, pillow-block-type ball or roller bearings with the following:
 - a. Rate Bearing Life: ABMA 9 or ABMA 11, L-50 of 400,000 hours.
 - 4. Belt Drives: Factory mounted, with final alignment and belt adjustment made after installation.
 - a. Service Factor Based on Fan Motor: 1.5.
 - 5. Pulleys: Cast iron or steel with split, tapered bushing, dynamically balanced at factory.
 - 6. Motor Pulleys: Adjustable pitch, selected so pitch adjustment is at middle of adjustment range at fan design conditions.
 - 7. Belts: Oil resistant, nonsparking, and nonstatic; matched for multiple belt drives.
 - 8. Motor Mount: Adjustable for belt tensioning.
 - 8. Vibration Control: Install fans on restrained open-spring vibration isolators, minimum 1-inch (25-mm) static deflection, with side snubbers.
- D. Fan-Section Source Quality Control: The following factory tests are required.
 - 1. Sound Power Level Ratings: Comply with AMCA 301, "Methods for Calculating Fan Sound Ratings from Laboratory Test Data." Test fans according to AMCA 300, "Reverberant Room Method for Sound Testing of Fans." Fans shall bear AMCA-certified sound ratings seal.
 - 2. Factory test fan performance for flow rate, pressure, power, air density, rotation speed, and efficiency. Establish ratings according to AMCA 210, "Laboratory Methods of Testing Fans for Rating."

1.6 BASIC MOTOR REQUIREMENTS

- A. Basic requirements apply to mechanical equipment motors, unless otherwise indicated.

- B. Frequency Rating: 50 Hz.
- C. Voltage Rating: 415 VOLT 3 PHASE to which motor is connected.
- D. Temperature Rating: 50 deg C maximum temperature rise at 40 deg C ambient for continuous duty at full load (Class F Insulation).
- E. Service Factor: 1.15 for polyphase motors
- F. Motor Construction: NEMA MG-1, general purpose, and continuous duty, Design B.

Bases: Adjustable.

- G Capacity and Torque Characteristics: Rated for continuous duty and sufficient to start, accelerate, and operate connected loads at designated speeds, in indicated environment, with indicated operating sequence, and without exceeding nameplate ratings or considering service factor.
- H. Enclosure: Open dripproof, unless otherwise indicated.

1.7 POLYPHASE MOTORS

- A. Description: NEMA MG 1, medium induction motor.
 - 1. Design Characteristics: NEMA MG 1, Design B, unless otherwise indicated.
 - 2. Energy-Efficient Design: Premium efficiency E-3 type.
 - 3. Stator: Copper windings, unless otherwise indicated. Multispeed motors have separate winding for each speed.
 - 4. Rotor: Squirrel cage, unless otherwise indicated.
 - 5. Bearings: Double-shielded, prelubricated ball bearings suitable for radial and thrust loading.
 - 6. Temperature Rise: Match insulation rating, unless otherwise indicated.
 - 7. Insulation: Class F, unless otherwise indicated.
- B. Motors Used with Reduced-Inrush Controllers: Match wiring connection requirements for indicated controller, with required motor leads brought to motor terminal box to suit control method.
- C. Rugged-Duty Motors: Where indicated, motors are totally enclosed with 1.25 minimum service factor, greased bearings, integral condensate drains, and capped relief vents. Windings are insulated with non-hygroscopic material. External finish is chemical-resistant paint over corrosion-resistant primer.
- D. Source Quality Control: Perform the following routine tests according to NEMA MG 1:
 - 1. Measurement of winding resistance.
 - 2. No-load readings of current and speed at rated voltage and frequency.
 - 3. Locked rotor current at rated frequency.
 - 4. High-potential test.
 - 5. Alignment.
- E. Bearings: The following features are required:
 - 5. Ball or roller bearings with inner and outer shaft seals.
 - 6. Grease lubricated.
 - 7. Designed to resist thrust loading where belt drives or other drives produce lateral or axial thrust in motor.
- F. Enclosure Type: The following features are required:
 - 1. Open dripproof motors where satisfactorily housed or remotely located during operation.
 - 2. Guarded dripproof motors where exposed to contact by employees or building occupants.
- G. Overload Protection: Built-in, automatic reset, thermal overload protection.
- H. Noise Rating: Quiet.

- I. Efficiency: Energy-efficient motors shall have a minimum efficiency as scheduled according to IEEE 112, Test Method B. If efficiency is not specified, motors shall have a higher efficiency than "average standard industry motors" according to IEEE 112, Test Method B.
- J. Nameplate: Indicate full identification of manufacturer, ratings, characteristics, construction, and special features.
- K. Starters, Electrical Devices, and Wiring: Electrical devices and connections are specified in Division 16 Sections.

1.8 COILS

- A. Coil Sections: Common or individual, insulated, galvanized steel casings for heating and cooling coils. Design and construct to facilitate removal and replacement of coil for maintenance and to assure full airflow through coils.
- B. Coil Construction: Rigidly supported across full face, pitched to allow drainage.
 - 1. Fins: Aluminum, mechanically bonded to tubes.
 - 2. Tubes: Seamless copper.
 - 3. Coil Casing: Galvanized steel.
 - 4. Headers for Water Coils: Steel, or copper with connections for drain valve and air vent, and threaded piping connections.
- C. Water Coils: Drainable with threaded plugs, serpentine with return bends in smaller sizes and with return headers in larger sizes.
- D. Coil-Performance Tests: Factory-test cooling and heating coils, except sprayed surface coils for rating according to ARI 410, "Forced-Circulation Air-Cooling and Air-Heating Coils."

1.8 DAMPERS

- A. General: Leakage rate, according to AMCA 500, "Test Methods for Louvers, Dampers and Shutters," shall not exceed 2 percent of air quantity at 2000-fpm (10-m/s) face velocity through damper and 4-inch wg (1000-Pa) pressure differential.
 - 1. Damper operators shall be electrically operated. Actuator (make Anergy or Honey well) shall be compatible with BMS SYSTEM (Make: Automatic logic control)

1.9 FILTER SECTION

- A. Description: Type >B= - Factory-fabricated, dry, extended-surface filters with holding frames and having performance characteristics as indicated. Provide pre-filters prior to all extended surface filters. The combination filters for HEPA air filtration should be designed for this unit.
- B. Media: Bag filters and pre filters combined to form HEPA filters and held by self-supporting wire frames.
- C. Frame: Nonflammable, with suitable fasteners and gaskets to hold media and media frame and to prevent unfiltered air from passing between media frames and holding devices.
- D. Filter Section: Provide filter media holding frames arranged for flat or angular orientation, with access doors on both sides of unit.
- E. Ratings: A HEPA filter is required to remove at least 99.97% of airborne particles down to 0.3u in size (in diameter or in their longest dimension). Provide filters with rated face velocity of 2.5 m/s, initial resistance of 75 Pa with 50 to 60 percent ASHRAE 52 efficiency, and 150 Pa with 90 to 95 percent efficiency, and final rated resistance of 300 Pa.

CLAUSES FOR PURCHASE ORDERS AND BLANKET PURCHASE
AGREEMENTS AWARDED BY OVERSEAS CONTRACTING ACTIVITIES
(Current thru FAC 2005-73-75)

COMMERCIAL ITEMS

FAR 52.252-2 Clauses Incorporated By Reference (FEB 1998)

This purchase order or BPA incorporates the following clauses by reference, with the same force and effect as if they were given in full text. Upon request, the Contracting Officer will make their full text available. Also, the full text of a clause may be accessed electronically at this address: <https://www.acquisition.gov/far>

DOSAR clauses may be accessed at: <http://www.statebuy.state.gov/dosar/dosartoc.htm>

FEDERAL ACQUISITION REGULATION (48 CFR Chapter 1) CLAUSES

NUMBER TITLE DATE

52.204-9 Personal Identity Verification of Contractor Personnel (if contractor requires physical access to a federally-controlled facility or access to a Federal information system) JAN 2011

52.212-4 Contract Terms and Conditions – Commercial Items (Alternate I (MAY 2014) of 52.212-4 applies if the order is time-and-materials or labor-hour) MAY 2014

52.225-19 Contractor Personnel in a Diplomatic or Consular Mission Outside the United States (applies to services at danger pay posts only) MAR 2008

52.227-19 Commercial Computer Software License (if order is for software) DEC 2007

52.228-3 Workers' Compensation Insurance (Defense Base Act) (if order is for services and contractor employees are covered by Defense Base Act insurance) JUL 2014

52.228-4 Workers' Compensation and War-Hazard Insurance (if order is for services and contractor employees are not covered by Defense Base Act insurance) APR 1984

The following clause is provided in full text:

52.212-5 CONTRACT TERMS AND CONDITIONS REQUIRED TO IMPLEMENT STATUTES OR EXECUTIVE ORDERS—COMMERCIAL ITEMS (JUN 2014)

(a) The Contractor shall comply with the following Federal Acquisition Regulation (FAR) clauses, which are incorporated in this contract by reference, to implement

provisions of law or Executive orders applicable to acquisitions of commercial items: (1) 52.222-50, Combating Trafficking in Persons (Feb 2009) (22 U.S.C. 7104(g)).

___ Alternate I (Aug 2007) of 52.222-50 (22 U.S.C. 7104(g)). (2) 52.233-3, Protest After Award (AUG 1996) (31 U.S.C. 3553). (3) 52.233-4, Applicable Law for Breach of Contract Claim (OCT 2004)"(Public Laws 108-77 and 108-78 (19 U.S.C. 3805 note)).

(b) The Contractor shall comply with the FAR clauses in this paragraph (b) that the Contracting Officer has indicated as being incorporated in this contract by reference to implement provisions of law or Executive orders applicable to acquisitions of commercial items:

[Contracting Officer: check as appropriate.] ___ (1) 52.203-6, Restrictions on Subcontractor Sales to the Government (Sept 2006), with Alternate I (Oct 1995) (41 U.S.C. 4704 and 10 U.S.C. 2402). ___ (2) 52.203-13, Contractor Code of Business Ethics and Conduct (Apr 2010) (41 U.S.C. 3509). ___ (3) 52.203-15, Whistleblower Protections under the American Recovery and Reinvestment Act of 2009 (June 2010) (Section 1553 of Pub. L. 111-5). (Applies to contracts funded by the American Recovery and Reinvestment Act of 2009.) ___ (4) 52.204-10, Reporting Executive Compensation and First-Tier Subcontract Awards (Jul 2013) (Pub. L. 109-282) (31 U.S.C. 6101 note).

___ (5) [Reserved]. ___ (6) 52.204-14, Service Contract Reporting Requirements (Jan 2014) (Pub. L. 111-117, section 743 of Div. C). ___ (7) 52.204-15, Service Contract Reporting Requirements for Indefinite-Delivery Contracts (Jan 2014) (Pub. L. 111-117, section 743 of Div. C). ___ (8) 52.209-6, Protecting the Government's Interest When Subcontracting with Contractors Debarred, Suspended, or Proposed for Debarment. (Aug 2013) (31 U.S.C. 6101 note). ___ (9) 52.209-9, Updates of Publicly Available Information Regarding Responsibility Matters (Jul 2013) (41 U.S.C. 2313). ___ (10) 52.209-10, Prohibition on Contracting with Inverted Domestic Corporations (May 2012) (section 738 of Division C of Pub. L. 112-74, section 740 of Division C of Pub. L. 111-117, section 743 of Division D of Pub. L. 111-8, and section 745 of Division D of Pub. L. 110-161). ___ (11) 52.219-3, Notice of HUBZone Set-Aside or Sole-Source Award (Nov 2011) (15 U.S.C. 657a). ___ (12) 52.219-4, Notice of Price Evaluation Preference for HUBZone Small Business Concerns (JAN 2011) (if the offeror elects to waive the preference, it shall so indicate in its offer) (15 U.S.C. 657a).

___ (13) [Reserved] ___ (14)(i) 52.219-6, Notice of Total Small Business Set-Aside (Nov 2011) (15 U.S.C. 644).

___ (ii) Alternate I (Nov 2011).

___ (iii) Alternate II (Nov 2011). ___ (15)(i) 52.219-7, Notice of Partial Small Business Set-Aside (June 2003) (15 U.S.C. 644). ___ (ii) Alternate I (Oct 1995) of 52.219-7. ___ (iii) Alternate II (Mar 2004) of 52.219-7. ___ (16) 52.219-8, Utilization of Small Business Concerns (May 2014) (15 U.S.C. 637(d)(2) and (3)). ___ (17)(i) 52.219-9, Small Business Subcontracting Plan (Jul 2013) (15 U.S.C. 637(d)(4)). ___ (ii) Alternate I (Oct 2001) of

52.219-9. __ (iii) Alternate II (Oct 2001) of 52.219-9. __ (iv) Alternate III (Jul 2010) of 52.219-9. __ (18) 52.219-13, Notice of Set-Aside of Orders (Nov 2011)(15 U.S.C. 644(r)). __ (19) 52.219-14, Limitations on Subcontracting (Nov 2011) (15 U.S.C. 637(a)(14)). __ (20) 52.219-16, Liquidated Damages—Subcontracting Plan (Jan 1999) (15 U.S.C. 637(d)(4)(F)(i)). __ (21)(i) 52.219-23, Notice of Price Evaluation Adjustment for Small Disadvantaged Business Concerns (OCT 2008) (10 U.S.C. 2323) (if the offeror elects to waive the adjustment, it shall so indicate in its offer). __ (ii) Alternate I (June 2003) of 52.219-23. __ (22) 52.219-25, Small Disadvantaged Business Participation Program—Disadvantaged Status and Reporting (Jul 2013) (Pub. L. 103-355, section 7102, and 10 U.S.C. 2323). __ (23) 52.219-26, Small Disadvantaged Business Participation Program—Incentive Subcontracting (Oct 2000) (Pub. L. 103-355, section 7102, and 10 U.S.C. 2323). __ (24) 52.219-27, Notice of Service-Disabled Veteran-Owned Small Business Set-Aside (Nov 2011) (15 U.S.C. 657 f). __ (25) 52.219-28, Post Award Small Business Program Rerepresentation (Jul 2013) (15 U.S.C. 632(a)(2)). __ (26) 52.219-29, Notice of Set-Aside for Economically Disadvantaged Women-Owned Small Business (EDWOSB) Concerns (Jul 2013) (15 U.S.C. 637(m)). __ (27) 52.219-30, Notice of Set-Aside for Women-Owned Small Business (WOSB) Concerns Eligible Under the WOSB Program (Jul 2013) (15 U.S.C. 637(m)). __ (28) 52.222-3, Convict Labor (June 2003) (E.O. 11755). __ (29) 52.222-19, Child Labor—Cooperation with Authorities and Remedies (Jan 2014) (E.O. 13126). __ (30) 52.222-21, Prohibition of Segregated Facilities (Feb 1999). __ (31) 52.222-26, Equal Opportunity (Mar 2007) (E.O. 11246). __ (32) 52.222-35, Equal Opportunity for Veterans (Sep 2010)(38 U.S.C. 4212). __ (33) 52.222-36, Affirmative Action for Workers with Disabilities (Oct 2010) (29 U.S.C. 793). __ (34) 52.222-37, Employment Reports on Veterans (SEP 2010) (38 U.S.C. 4212). __ (35) 52.222-40, Notification of Employee Rights Under the National Labor Relations Act (Dec 2010) (E.O. 13496). __ (36) 52.222-54, Employment Eligibility Verification (AUG 2013). (Executive Order 12989). (Not applicable to the acquisition of commercially available off-the-shelf items or certain other types of commercial items as prescribed in 22.1803.) __ (37)(i) 52.223-9, Estimate of Percentage of Recovered Material Content for EPA–Designated Items (May 2008) (42 U.S.C. 6962(c)(3)(A)(ii)). (Not applicable to the acquisition of commercially available off-the-shelf items.) __ (ii) Alternate I (May 2008) of 52.223-9 (42 U.S.C. 6962(i)(2)(C)). (Not applicable to the acquisition of commercially available off-the-shelf items.) __ (38)(i) 52.223-13, Acquisition of EPEAT®-Registered Imaging Equipment (JUN 2014) (E.O. 13423 and 13514). __ (ii) Alternate I (Jun 2014) of 52.223-13. __ (39)(i) 52.223-14, Acquisition of EPEAT®-Registered Televisions (E.O. 13423 and 13514). __ (ii) Alternate I (Jun 2014) of 52.223-14. __ (40) 52.223-15, Energy Efficiency in Energy-Consuming Products (DEC 2007) (42 U.S.C. 8259b). __ (41)(i) 52.223-16, Acquisition of EPEAT®-Registered Personal Computer Products (JUN 2014) (E.O. 13423 and 13514). __ (ii) Alternate I (Jun 2014) of 52.223-16. __ (42) 52.223-18, Encouraging Contractor Policies to Ban Text Messaging While Driving (AUG 2011) (E.O. 13513). __ (43) 52.225-1, Buy American—Supplies (May 2014) (41 U.S.C. chapter 83). __ (44)(i) 52.225-3, Buy American—Free Trade Agreements—Israeli Trade Act (May 2014) (41 U.S.C. chapter 83, 19 U.S.C. 3301 note, 19 U.S.C.

2112 note, 19 U.S.C. 3805 note, 19 U.S.C. 4001 note, Pub. L. 103-182, 108-77, 108-78, 108-286, 108-302, 109-53, 109-169, 109-283, 110-138, 112-41, 112-42, and 112-43. __ (ii) Alternate I (May 2014) of 52.225-3. __ (iii) Alternate II (May 2014) of 52.225-3. __ (iv) Alternate III (May 2014) of 52.225-3. __ (45) 52.225-5, Trade Agreements (NOV 2013) (19 U.S.C. 2501, et seq., 19 U.S.C. 3301 note). __ (46) 52.225-13, Restrictions on Certain Foreign Purchases (June 2008) (E.O.'s, proclamations, and statutes administered by the Office of Foreign Assets Control of the Department of the Treasury). __ (47) 52.225-26, Contractors Performing Private Security Functions Outside the United States (Jul 2013) (Section 862, as amended, of the National Defense Authorization Act for Fiscal Year 2008; 10 U.S.C. 2302 Note). __ (48) 52.226-4, Notice of Disaster or Emergency Area Set-Aside (Nov 2007) (42 U.S.C. 5150). __ (49) 52.226-5, Restrictions on Subcontracting Outside Disaster or Emergency Area (Nov 2007) (42 U.S.C. 5150). __ (50) 52.232-29, Terms for Financing of Purchases of Commercial Items (Feb 2002) (41 U.S.C. 4505, 10 U.S.C. 2307(f)). __ (51) 52.232-30, Installment Payments for Commercial Items (Oct 1995) (41 U.S.C. 4505, 10 U.S.C. 2307(f)). __ (52) 52.232-33, Payment by Electronic Funds Transfer—System for Award Management (Jul 2013) (31 U.S.C. 3332). __ (53) 52.232-34, Payment by Electronic Funds Transfer—Other than System for Award Management (Jul 2013) (31 U.S.C. 3332). __ (54) 52.232-36, Payment by Third Party (May 2014) (31 U.S.C. 3332). __ (55) 52.239-1, Privacy or Security Safeguards (Aug 1996) (5 U.S.C. 552a). __ (56)(i) 52.247-64, Preference for Privately Owned U.S.-Flag Commercial Vessels (Feb 2006) (46 U.S.C. Appx. 1241(b) and 10 U.S.C. 2631). __ (ii) Alternate I (Apr 2003) of 52.247-64.

(c) The Contractor shall comply with the FAR clauses in this paragraph (c), applicable to commercial services, that the Contracting Officer has indicated as being incorporated in this contract by reference to implement provisions of law or Executive orders applicable to acquisitions of commercial items:

[Contracting Officer: check as appropriate.]

__ (1) 52.222-41, Service Contract Labor Standards (May 2014) (41 U.S.C. chapter 67).
__ (2) 52.222-42, Statement of Equivalent Rates for Federal Hires (May 2014) (29 U.S.C. 206 and 41 U.S.C. chapter 67). __ (3) 52.222-43, Fair Labor Standards Act and Service Contract Labor Standards-Price Adjustment (Multiple Year and Option Contracts) (May 2014) (29 U.S.C. 206 and 41 U.S.C. chapter 67). __ (4) 52.222-44, Fair Labor Standards Act and Service Contract Labor Standards—Price Adjustment (May 2014) (29 U.S.C. 206 and 41 U.S.C. chapter 67). __ (5) 52.222-51, Exemption from Application of the Service Contract Labor Standards to Contracts for Maintenance, Calibration, or Repair of Certain Equipment—Requirements (May 2014) (41 U.S.C. chapter 67). __ (6) 52.222-53, Exemption from Application of the Service Contract Labor Standards to Contracts for Certain Services—Requirements (May 2014) (41 U.S.C. chapter 67). __ (7) 52.222-17, Nondisplacement of Qualified Workers (May 2014) (E.O.13495). __ (8) 52.226-6, Promoting Excess Food Donation to Nonprofit Organizations (May 2014) (42 U.S.C. 1792). __ (9) 52.237-11, Accepting and Dispensing of \$1 Coin (Sept 2008) (31 U.S.C. 5112(p)(1)).

(d) Comptroller General Examination of Record. The Contractor shall comply with the provisions of this paragraph (d) if this contract was awarded using other than sealed bid, is in excess of the simplified acquisition threshold, and does not contain the clause at 52.215-2, Audit and Records—Negotiation.

(1) The Comptroller General of the United States, or an authorized representative of the Comptroller General, shall have access to and right to examine any of the Contractor's directly pertinent records involving transactions related to this contract.

(2) The Contractor shall make available at its offices at all reasonable times the records, materials, and other evidence for examination, audit, or reproduction, until 3 years after final payment under this contract or for any shorter period specified in FAR Subpart 4.7, Contractor Records Retention, of the other clauses of this contract. If this contract is completely or partially terminated, the records relating to the work terminated shall be made available for 3 years after any resulting final termination settlement. Records relating to appeals under the disputes clause or to litigation or the settlement of claims arising under or relating to this contract shall be made available until such appeals, litigation, or claims are finally resolved.

(3) As used in this clause, records include books, documents, accounting procedures and practices, and other data, regardless of type and regardless of form. This does not require the Contractor to create or maintain any record that the Contractor does not maintain in the ordinary course of business or pursuant to a provision of law.

(e)(1) Notwithstanding the requirements of the clauses in paragraphs (a), (b), (c), and (d) of this clause, the Contractor is not required to flow down any FAR clause, other than those in this paragraph (e)(1) in a subcontract for commercial items. Unless otherwise indicated below, the extent of the flow down shall be as required by the clause— (i) 52.203-13, Contractor Code of Business Ethics and Conduct (Apr 2010) (41 U.S.C. 3509). (ii) 52.219-8, Utilization of Small Business Concerns (May 2014) (15 U.S.C. 637(d)(2) and (3)), in all subcontracts that offer further subcontracting opportunities. If the subcontract (except subcontracts to small business concerns) exceeds \$650,000 (\$1.5 million for construction of any public facility), the subcontractor must include 52.219-8 in lower tier subcontracts that offer subcontracting opportunities. (iii) 52.222-17, Nondisplacement of Qualified Workers (May 2014) (E.O. 13495). Flow down required in accordance with paragraph (l) of FAR clause 52.222-17. (iv) 52.222-26, Equal Opportunity (Mar 2007) (E.O. 11246). (v) 52.222-35, Equal Opportunity for Veterans (Sep 2010) (38 U.S.C. 4212). (vi) 52.222-36, Affirmative Action for Workers with Disabilities (Oct 2010) (29 U.S.C. 793). (vii) 52.222-40, Notification of Employee Rights Under the National Labor Relations Act (Dec 2010) (E.O. 13496). Flow down required in accordance with paragraph (f) of FAR clause 52.222-40. (viii) 52.222-41, Service Contract Labor Standards (May 2014) (41 U.S.C. chapter 67). (ix) 52.222-50, Combating Trafficking in Persons (Feb 2009) (22 U.S.C. 7104(g)). ___Alternate I (Aug 2007) of 52.222-50 (22 U.S.C. 7104(g)). (x) 52.222-51, Exemption from Application of the Service Contract Labor Standards to Contracts for Maintenance, Calibration, or

Repair of Certain Equipment-Requirements (May 2014) (41 U.S.C. chapter 67). (xi) 52.222-53, Exemption from Application of the Service Contract Labor Standards to Contracts for Certain Services-Requirements (May 2014) (41 U.S.C. chapter 67). (xii) 52.222-54, Employment Eligibility Verification (AUG 2013). (xiii) 52.225-26, Contractors Performing Private Security Functions Outside the United States (Jul 2013) (Section 862, as amended, of the National Defense Authorization Act for Fiscal Year 2008; 10 U.S.C. 2302 Note). (xiv) 52.226-6, Promoting Excess Food Donation to Nonprofit Organizations (May 2014) (42 U.S.C. 1792). Flow down required in accordance with paragraph (e) of FAR clause 52.226-6. (xv) 52.247-64, Preference for Privately Owned U.S.-Flag Commercial Vessels (Feb 2006) (46 U.S.C. Appx. 1241(b) and 10 U.S.C. 2631). Flow down required in accordance with paragraph (d) of FAR clause 52.247-64.

(2) While not required, the contractor may include in its subcontracts for commercial items a minimal number of additional clauses necessary to satisfy its contractual obligations.

(End of clause)

DEPARTMENT OF STATE ACQUISITION REGULATION (48 CFR Chapter 6) CLAUSES

NUMBER TITLE DATE

652.225-71 Section 8(a) of the Export Administration Act of 1979, As Amended (if order exceeds simplified acquisition threshold) AUG 1999

652.229-70 Excise Tax Exemption Statement for Contractors Within the United States (for supplies to be delivered to an overseas post) JUL 1988

652.229-71 Personal Property Disposition at Posts Abroad AUG 1999

652.237-72 Observance of Legal Holidays and Administrative Leave (for services where performance will be on-site in a Department of State facility) APR 2004

652.239-71 Security Requirements for Unclassified Information Technology Resources (for orders that include information technology resources or services in which the contractor will have physical or electronic access to Department information that directly supports the mission of the Department) SEP 2007

652.242-70 Contracting Officer's Representative (if a COR will be named for the order) Fill-in for paragraph b: "The COR is _____" AUG 1999

652.242-71 Notice of Shipments (for overseas shipment of supplies) JUL 1988

652.242-73 Authorization and Performance AUG 1999

652.243-70 Notices AUG 1999

The following clause is provided in full text, and is applicable for orders for services that will require contractor employees to perform on-site at a DOS location and/or that require contractor employees to have access to DOS information systems:

652.204-70 Department of State Personal Identification Card Issuance Procedures (MAY 2011)

(a) The Contractor shall comply with the Department of State (DOS) Personal Identification Card Issuance Procedures for all employees performing under this contract who require frequent and continuing access to DOS facilities, or information systems. The Contractor shall insert this clause in all subcontracts when the subcontractor's employees will require frequent and continuing access to DOS facilities, or information systems.

(b) The DOS Personal Identification Card Issuance Procedures may be accessed at <http://www.state.gov/m/ds/rls/rpt/c21664.htm>.

(End of clause)